


PROPRIETARY AND CONFIDENTIAL
 THE INFORMATION CONTAINED IN THIS
 DRAWING IS THE SOLE PROPERTY OF
 GNB CORPORATION. ANY
 REPRODUCTION IN PART OR AS A WHOLE
 WITHOUT THE WRITTEN PERMISSION OF
 GNB CORPORATION IS PROHIBITED.

3472/1

REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
	A	REVISED MODEL TO MATCH MFG. PROCESSES	6/9/10	MKM2
	B	REVISED TOLERANCE BLOCK, GD&T TOLERANCE WAS .05, NOW .03	6/24/10	MKM2
	C	REVISED TOLERANCES ON BOLT CIRCLES, 68.25 WAS 68.50; CALLED OUT FLANGE THICKNESSES. LARGE FLANGE IS NOW 1.5 THK. WAS 1.0	7/20/10	MKM2
	D	ADDED FINISH CALL-OUTS, RELEASED TO PRODUCTION	8/20/2010	MKM2



- NOTES
- VACUUM SEALING SURFACE ✓
 - ALL CONFLAT FLANGES ARE NON-ROTATABLE WITH THRU HOLES. ✓

MATERIAL: AISI 304/AISI 304L DUAL CERT PER SA240

UNLESS OTHERWISE SPECIFIED: WEIGHT: 1276.64#

DIMENSIONS ARE IN INCHES

TOLERANCES: FINISH 125

ANGULAR: ± 0°30'

.XX ± .06

.XXX ± .005

UNSPECIFIED FILLETS: R.015

BREAK EDGES .010x45°

REMOVE ALL BURRS

THIRD ANGLE PROJECTION

APPROVALS	DATE
DRAFTER MKM2	6/9/10
CHECKER RW	6/14/10
ENGINEER MKM2	6/9/10

GNB CORPORATION
 SCIENTIFIC AND INDUSTRIAL EQUIPMENT
 3200 DWIGHT RD. SUITE 100
 ELK GROVE, CA, 95758
 916-395-3003 FAX: 916-395-3363
 www.gnbvalves.com

TITLE: OUTLINE, ADAPTER A-16

DO NOT SCALE DRAWING

B DWG. NO. 114141-00

SCALE: 1:24

SHEET 1 OF 1

REV D

Bake Out Data Collection Sheet

Date: 5/6/11 Technician: Clancy Bleily Component: SA-16 & A-17

	Bake Out Day 1 ^{5/6}			Bake Out Day 2 ^{5/7}			Bake Out Day 3 ^{5/8}		
	Time	Temp	Pressure	Time	Temp	Pressure	Time	Temp	Pressure
1:00 AM									
2:00 AM									
3:00 AM									
4:00 AM									
5:00 AM									
6:00 AM				6:00	102	6.4 ⁻⁶			
7:00 AM				7:00	108	6.0 ⁻⁶			
8:00 AM				8:00	114	6.2 ⁻⁶			
9:00 AM				9:00	120	6.9 ⁻⁶			
10:00 AM				10:00	126	7.9 ⁻⁶			
11:00 AM				11:00	134	8.6 ⁻⁶			
12:00 PM				12:00	140	8.0 ⁻⁶	12:00	150	4.8 ⁻⁶
1:00 PM	1:00	30°	8.9 ⁻⁶	1:00	146	9.5 ⁻⁶			
2:00 PM	2:00	36°	8.0 ⁻⁶	2:00	150	9.7 ⁻⁶			
3:00 PM	3:00	42°	7.2 ⁻⁶						
4:00 PM	4:00	48°	7.8 ⁻⁶						
5:00 PM	5:00	54°	7.4 ⁻⁶						
6:00 PM	6:00	60	7.7 ⁻⁶						
7:00 PM	7:00	66	8.1 ⁻⁶						
8:00 PM	8:00	72	9.0 ⁻⁶						
9:00 PM	9:00	78	9.1 ⁻⁶						
10:00 PM	10:00	84	1.1 ⁻⁵						
11:00 PM	11:00	90	1.2 ⁻⁵						
12:00 AM	12:00	96	1.4 ⁻⁵						

Bake Out Data Collection Sheet

Date: / / Technician: Component:

1:00 5.6-11 Test heater function - TC function
2:00 38° set point all looks good
3:00 42° set point all looks good
3:10 Install jackets.
6:40 RGA Turn on

87°

5-9-11 : 2:00 pm Start ramp down

A-16 view pit cars 165° 158° 156°
A-17 view RA cars 135° 132° 134°

5-10 - Start disassemble for final leaktest WRS disconnected at 4:00 so last 2 pressure readings not available.

GNB - LIGO CLEANLINESS TESTING RECORD			
<i>Component (check only 1)</i>			
<input checked="" type="radio"/> 114141-00 A16 Adptr	<input type="radio"/> 114142-00 A17 Adptr	<input type="radio"/> 114143-00 A18 Adptr	<input type="radio"/> 114144-00 Mid-St Sp
<input type="radio"/> 114146-00 MC-B	<input type="radio"/> 114146-01 MC-B	<input type="radio"/> 114146-02 MC-B	<input type="radio"/> 114146-03 MC-B
<input type="radio"/> 114145-00 MC-A	<input type="radio"/> 114425-00S Sept. Plt.		
<input type="radio"/> 114424-01S Sept. Plt.	<input type="radio"/> 114424-02S Sept. Plt.	<input type="radio"/> 114424-03S Sept. Plt.	<input type="radio"/> 114424-04S Sept. Plt.
<input type="radio"/> Other Items (pr/description/quantity): ALL SAMPLES ARE ISOPROPYL ALCOHOL (IPA), HRGC/HPLC TRACE GRADE			
Revision: 114434005 Serial Number: 85109			
<i>Samples</i>			
Sample(s) Taken By: RICH REED / CLAUDE BIELEY			
Date: 4/23/11			<i>Result Comments</i>
Sample 1 - Bottle Number & Area Sampled: #1 - BASELINE FILTER ONLY IPA			
Sample 2 - Bottle Number & Area Sampled: #2 - FILTER & COLLECTION TOOL			
Sample 3 - Bottle Number & Area Sampled: #3 - A-16 INSIDE ROLL UP BELLOW WELD SEAM			
Sample 4 - Bottle Number & Area Sampled: #4 - A-16 LARGE FLANGE @ 4 o'clock			
Sample 5 - Bottle Number & Area Sampled: #5 - A-16 1/2 NIPPLE @ 9 o'clock			
Sample 6 - Bottle Number & Area Sampled:			
AstroPak PO Number: LC-0107-01			
Ship Date, Carrier, Tracking#:			
<i>Test Result Disposition</i>			
AstroPak Test Report Attached? (y/n):		Is this a Repeated Test? (y/n):	
Is Component Accepted or Rejected?			
Title:	Signature:	Date:	
Comments (enter here and/or to right of sample area descriptions):			



ASTRO PAK

astropak.com

12201 Pangborn Avenue, Downey, CA 90241 (562) 293-3557 Fax (562) 803-3870
For inquiries regarding in-process orders, please call Customer Service at (562) 293-3552 or (866) 492-7876 ext. 3552

Certificate of Compliance

Astro Pak Corporation hereby certifies that all processes required by your purchase order were performed and that all materials used were in accordance with the applicable specification(s). Any evidence of tampering with the package or seals prior to installation without specific approval, nullifies this certification.


Customer GNB 3200 Dwight Road Suite 100 Elk Grove, CA 95758
P.O. LC-0107-01 Log 93717021 Total Quantity 5 Date 4/29/2011

The process specification or service performed: Particle and NVR Testing

Tested per IEST-STD-CC1246D for particulate levels and reported results

Line #	Qty	Part #	Part Description	Extended Description	Serial #s	Job #
1	1	Bottle #1	Baseline Filter, 100 ml sample			
2	1	Bottle #2	Filter & Collection Tool, 100 ml sample			
3	1	Bottle #3	A-16 Inside Roll Up Bellow Weld Seam, 100 ml sample			
4	1	Bottle #4	A-16 Large Flange @ 4 o'clock, 100 ml sample			
5	1	Bottle #5	A-16 Large Flange @ 9 o'clock, 100 ml sample			

Quality Assurance


Martin Smith, QA Manager



Date

APR 29 2011

Source Required No

Date



Astro Pak Corporation's Precision Cleaning Facility - Downey CA is an AS 9100B:2004 and ISO 9001:2008 registered facility.

Cert. #42548



1 of 1



Certified Test Report

Customer: GNB Corporation

PO: LC-0107-01

Log # 93717021

Description: Samples

Specification: IEST-STD-CC1246D, Level 100A/20

Acceptance Criteria and Results

Size/microns	> 5	> 15	> 25	> 50	> 100	NVR
Allowable	1,780	264	78	11	1	0.05 mg
1	477	77	13	3	0	0.21 mg
2	1,140	140	30	5	0	0.25 mg
Δ of 3	116	16	6	3	1	0.03 mg
Δ of 4	222	22	0	1	0	0.02 mg
IEST-STD-CC1246D Levels	69	71	60	70	NA	A/4.76
IEST-STD-CC1246D Levels	88	84	77	81	NA	A/4.76
IEST-STD-CC1246D Levels	45	43	47	70	100	A/33.3
IEST-STD-CC1246D Levels	55	48	NA	50	NA	A/50

1 = " 95% UCL = 521 particles > 5 μm / 0.1 m²; LCL = 437 "


2 = " 95% UCL = 1,207 particles > 5 μm / 0.1 m²; LCL = 1,077 "

Delta of 3 = " 95% UCL = 139 particles > 5 μm / 0.1 m²; LCL = 97 "

Delta of 4 = " 95% UCL = 253 particles > 5 μm / 0.1 m²; LCL = 195 "

NOTE: The graph below is merely a visual representation of the raw laboratory data reported above. The graph extrapolates the median cleanliness levels to form a graphable line.

IEST-STD-CC1246D, Level 100



Particle Size → < 100μ

Lab Tech: Sal Martinez
 Date/Time: 04/28/11 1700
 Relative Humidity: 45%
 Temp: 64° F
 Sample method: ASTM F303
 Test Method: ASTM F311, F312 & F331

THE ABOVE DATA HAS BEEN REVIEWED AND APPROVED

[Signature]
 AP 15
 Astro Pak Quality

APR 29 2011



Certified Test Report

Customer: GNB Corporation

PO: LC-0107-01

Log # 93717021

Description: Samples

Specification: IEST-STD-CC1246D, Level 100A/20

Acceptance Criteria and Results

Size/microns	> 5	> 15	> 25	> 50	> 100		NVR
Allowable	1,780	264	78	11	1		0.05 mg
Delta of 5	32	32	17	9	0		0.01 mg
**	*	*	*	*	*		*
IEST-STD-CC1246D Levels	28	54	65	95	NA		A/100
**	*	*	*	*	*		*

Delta of 5 = " 95% UCL = 45 particles > 5 μm / 0.1 m² ; LCL = 23 "


Test 6 = " NA "

Test 7 = " NA "

Test 8 = " NA "

NOTE: The graph below is merely a visual representation of the raw laboratory data reported above. The graph extrapolates the median cleanliness levels to form a graphable line.

IEST-STD-CC1246D , Level 100



Lab Tech: Sal Martinez
 Date/Time: 04/28/11 1700
 Relative Humidity: 45%
 Temp: 64° F
 Sample method: ASTM F303
 Test Method: ASTM F311, F312 & F331

THE ABOVE DATA HAS BEEN REVIEWED AND APPROVED

Sal Martinez
 APR 29 2011
 Astro Pak Quality

1ST A-16 & A-17 Final Leak Check



QP1750-A7

Subject: Leak Test Procedure (LIGO Only)
Revision: B

Page 4 of 4

GNB - LIGO LEAK TEST RECORD AND CERTIFICATION

Detector

Mdl: Varian VSMD301	SN: LL10074045	Cal. Exp. Date: 6-9-11	Tracer Gas: He4
Std Lk Rate: 9.1E-09		Std Response: 9.1E-08	
Component	(1)	(2)	(3)
Component Name	1 ST A-16	1 ST A-17	
GNB Drawing No. & Rev.	114141-00	114142-00	
Serial No.	85109	85111	

Leak Test Data

Pressure	.9 mtorr	.9 mtorr	
Duration	20 min	20 min	
Response	No Leak Detected	NO Leak Detected	
Leak Rate	Allowable: $\leq 1 \times 10^{-9}$ Torr-L/S		
Welds I, Measured	1.0^{-9} Torr L/S	1.0^{-9} Torr L/S	
Welds II, Measured	"	"	"
CF III, Measured	"	"	"

Performed By/Date: Marc Putz
Pre-Final Clean _____ Post Bakeout
Witnessed By: Clancy Blum Title: Lead Tech
Signature/Date: Clancy Blum 5-10-11

Comments:
Chambers isolated to having only the leak checker pumping on vessels during leak check. 20 minutes of heavy He flood area and no leaks detected

Annulus Pump-down

Allowable: $\leq 1 \times 10^{-5}$ Torr	Pass / Fail	Pass / Fail	Pass / Fail
Annulus1/Category IV	Pass		
Annulus1/Category V	1 ST A-16	1 ST A-17	
Measured Vacuum	1×10^{-5}	N/A	
Annulus2/Category IV			
Annulus2/Category V			
Measured Vacuum			

Performed By/Date: Clancy Blum
Witnessed By: _____ Signature/Date: Clancy Blum 5-10-11
Comments:

GNB - LIGO FINAL CLEANING RECORD				
This Version For MC or Mid-Station Tubes				
Component Name:	GNB Dwg Number:	Serial Number:	Date:	
A16 #1	114434-005	85109	4-21-11	
External Surfaces - Detergent Wash & Rinse				
Start Time: 1:00	End Time: 1:25			
VBS - Pre-Rinse / Component Heat-Up				
Start Time: 1:25	Rinse Water Temperature: 160°			
Int#1: 99.2	Int#2: 98.3	Int#3: 101.1	Ext#1: 99.4	Ext#2: 100.7
End Time: 2:15				
VBS - Detergent Wash				
Washing with Fixture-	Start Time:	End Time:		
Typical Surface Temps Attained:	#1: 99.4	#2: 100.2	#3: 98.7	
Washing with Wand(s)-	Start Time: 2:15	End Time: 3:00		
Area Location:	Approx Sq.Ft.:	Start Temp:	Time to get to 130F:	
#1 Top Flange	3	74		
#2 Roll Up	15	74		
#3 Bottom Flange with parts	10	74		
First DI Rinse				
Start Time: 3:00	End Time:	Rinse Duration at least 15 minutes? (y/n): 7		
Spot Check for Film or Residue				
Swab Coloration Evident? (y/n): N. If yes, comments & title/signature:				
4/23/11				
Final DI Rinse				
Start Time: 10:00	End Time:	Rinse Duration at least 15 minutes? (y/n):		
10:00 to 12:00 Nitrogen Blow Dry				
Start Time: 12:00	End Time: 12:15			
Operators:	1: Daniel Bradford 2: Clarence Reilly			
Comments:				
Visual Inspection (VC-Exterior / Vis+UV-VB Surfaces)				
Vacuum Boundary? (pass/fail): Pass	Title of Inspector: Clarence Reilly Lead Tech			
External Surfaces? (pass/fail): Pass	Signature/Date: Clarence Reilly 4/23/11			
Comments:				

GNB - LIGO LEAK TEST RECORD AND CERTIFICATION

Detector

Mdl: Varian VSMD301	SN: <u>LL10074095</u>	Cal. Exp. Date: <u>6-9-11</u>	Tracer Gas: He4
Std Lk Rate: <u>7.6E-8</u>	Std Response: <u>7.6E-8</u>		
Component	(1)	(2)	(3)
Component Name	<u>A-16 1st</u>		
GNB Drawing No. & Rev.	<u>114434-005</u>		
Serial No.	<u>85109</u>		

Leak Test Data

Pressure	<u>8.8 x 10⁻⁴</u>		
Duration			
Response	<u>Pass</u>		

Leak Rate Allowable: $\leq 1 \times 10^{-9}$ Torr-L/S

Welds I, Measured	<u>Pass</u>	<u>2.4 x 10⁻¹⁰</u>	
Welds II, Measured	<u>Pass</u>	<u>2.4 x 10⁻¹⁰</u>	
CF III, Measured	<u>Pass</u>	<u>2.4 x 10⁻¹⁰</u>	

Performed By/Date: 3-28-11 Clancy Pre-Final Clean Post Bakeout

Witnessed By: _____ Title: _____

Signature/Date: _____

Comments: _____

Annulus Pump-down

Allowable: $\leq 1 \times 10^{-5}$ Torr	Pass / Fail	Pass / Fail	Pass / Fail
Annulus1/CategoryIV	<u>Pass</u>		
Annulus1/CategoryV			
Measured Vacuum	<u>1 x 10⁻⁵</u>		
Annulus2/CategoryIV			
Annulus2/CategoryV			
Measured Vacuum			

Performed By/Date: Clancy 3/28/11

Witnessed By: _____ Signature/Date: _____

Comments: _____