



L1 AREA PLAN VIEW
SCALE: 1/2" = 1'-0"
SCALE IN FEET

DUCTLESS AIR CONDITIONER (AC) SCHEDULE												
SYMBOL	ROOM LOCATION	TYPE	COOLING			INDOOR UNIT		OUTDOOR UNIT		MFR	FEATURES	
			TOTAL CAPACITY (BTU)	SEER	MCA (AMPS)	V/PH	MODEL	MOCP (AMPS)	V/PH			MODEL
AC-1	LAE-L1	DUCTLESS WALL MOUNT	12,000	15.2	1.0	208/1	PKA-A12HA	15	208/1	PUV-A12NHA3	MTSUBISHI	PROVIDE LOW AMBIENT KIT, CONDENSATE PUMP.
AC-2	LAE-L1	DUCTLESS WALL MOUNT	12,000	15.2	1.0	208/1	PKA-A12HA	15	208/1	PUV-A12NHA3	MTSUBISHI	PROVIDE LOW AMBIENT KIT, WIRED THERMOSTAT

BOOSTER FAN (BF) SCHEDULE											
SYMBOL	LOCATION	TYPE	AIRFLOW (CFM)	STATIC PRESSURE (IN WG)	DRIVE	MOTOR		CONTROL	MFR/MODEL	FEATURES	
						HP	RPM				V/PH
SF-1	ABOVE LVA EQUIP CLOSET	IN-LINE AXIAL	300	0.75	DIRECT	1/2	1870	120/1	VFD/MANUAL ADJUST FOR ROOM PRESSURE	S&P INLINE MIXED FLOW DUCT FAN, SL-TD-250 (10')	PROVIDE WITH ROTARY SPEED CONTROL

NOTE: DWNER SHALL DETERMINE ELECTRICAL PANEL AND CIRCUIT FOR EQUIPMENT POWER.

DATE OF ISSUE				
REV No	DATE	BY	DESCRIPTION	APPROVED

DRAWN BY: GLH		DESIGN GM	
CHECKED BY:		HEI APPROVAL	

PROJECT NUMBER: 1036.01		CAD FILE: 1036M01	
L1 LASER AREA ENCLOSURE MECHANICAL PLAN & SCHEDULES			

PRINTED BY: GI on 9/13/2010 9:05 AM

CALIFORNIA INSTITUTE OF TECHNOLOGY
LIGO LIVINGSTON OBSERVATORY

HIBBS ENGINEERING, INC.
KENNEWICK, WASHINGTON

DRAWING NUMBER: 2392
REV: V1

DRAWING: LIGO-D1002392-V1