



L1 AREA PLAN VIEW  
SCALE: 1/2" = 1'-0"  
SCALE IN FEET



| DUCTLESS AIR CONDITIONER (AC) SCHEDULE |               |                     |                      |      |            |             |           |              |       |             |           |   |
|--|---------------|---------------------|----------------------|------|------------|-------------|-----------|--------------|-------|-------------|-----------|---|
| SYMBOL                                 | ROOM LOCATION | TYPE                | COOLING              |      |            | INDOOR UNIT |           | OUTDOOR UNIT |       | MFR         | FEATURES  |   |
|  |               |                     | TOTAL CAPACITY (BTU) | SEER | MCA (AMPS) | V/PH        | MODEL     | MOCP (AMPS)  | V/PH  |             |           | MODEL                                     |
| AC-1                                   | LAE-L1        | DUCTLESS WALL MOUNT | 12,000               | 15.2 | 1.0        | 208/1       | PKA-A12HA | 15           | 208/1 | PUV-A12NHA3 | MTSUBISHI | PROVIDE LOW AMBIENT KIT, CONDENSATE PUMP. |
| AC-2                                   | LAE-L1        | DUCTLESS WALL MOUNT | 12,000               | 15.2 | 1.0        | 208/1       | PKA-A12HA | 15           | 208/1 | PUV-A12NHA3 | MTSUBISHI | PROVIDE LOW AMBIENT KIT, WIRED THERMOSTAT |

NOTE: DWNER SHALL DETERMINE ELECTRICAL PANEL AND CIRCUIT FOR EQUIPMENT POWER.  
NOTE: PROVIDE HIGH LEVEL INDICATOR FOR CONDENSATE PUMP. LOCATE INDICATOR LIGHT AS SHOWN ON PLAN.

| SUPPLY FAN (SF) SCHEDULE |                         |               |               |                         |        |       |      |         |                                     |   |                                   |
|--------------------------|-------------------------|---------------|---------------|-------------------------|--------|-------|------|---------|-------------------------------------|---|-----------------------------------|
| SYMBOL                   | LOCATION                | TYPE          | AIRFLOW (CFM) | STATIC PRESSURE (IN WG) | DRIVE  | MOTOR |      | CONTROL | MFR/MODEL                           | FEATURES  |                                   |
|                          |                         |               |               |                         |        | HP    | RPM  |         |                                     |   | V/PH                              |
| SF-1                     | ABOVE LEVA EQUIP CLOSET | IN-LINE AXIAL | 300           | 0.75                    | DIRECT | 1/2   | 1870 | 120/1   | VFD/MANUAL ADJUST FOR ROOM PRESSURE | S&P INLINE MIXED FLOW DUCT FAN, SL-TD-250 (10") | PROVIDE WITH ROTARY SPEED CONTROL |

NOTE: DWNER SHALL DETERMINE ELECTRICAL PANEL AND CIRCUIT FOR EQUIPMENT POWER.