


SYMBOL	ROOM LOCATION	TYPE	COOLING		INDOOR UNIT		OUTDOOR UNIT		MFR	FEATURES	
			TOTAL CAPACITY (BTU)	SEER	MCA (AMPS)	V/PH	MOCP (AMPS)	V/PH			MODEL
AC-3	LAE-H2	DUCTLESS WALL MOUNT	12,000	15.2	1.0	208/1	208/1	208/1	PKA-A12HA	MITSUBISHI	PROVIDE LOW AMBIENT KIT, CONDENSATE PUMP, WIRED THERMOSTAT
AC-4	LAE-H2	DUCTLESS WALL MOUNT	12,000	15.2	1.0	208/1	208/1	208/1	PKA-A12HA	MITSUBISHI	PROVIDE LOW AMBIENT KIT, WIRED THERMOSTAT

NOTE: OWNER SHALL DETERMINE ELECTRICAL PANEL AND CIRCUIT FOR EQUIPMENT POWER.
 NOTE: PROVIDE HIGH LEVEL INDICATOR FOR CONDENSATE PUMP. LOCATE INDICATOR LIGHT AS SHOWN ON PLAN.

SYMBOL	LOCATION	TYPE	AIRFLOW (CFM)	STATIC PRESSURE (IN WG)	DRIVE	MOTOR		CONTROL	MFR/MODEL	FEATURES	
						HP	RPM				V/PH
SF-2	ABOVE LAE-AIR ENTRY AIR LOCK	IN-LINE AXIAL	300	0.75	DIRECT	1/2	1870	120/1	VFD/MANUAL ADJUST FOR ROOM PRESSURE	S&P IN-LINE MIXED FLOW DUCT FAN, SL-TD-250 (107)	PROVIDE WITH ROTARY SPEED CONTROL

SUPPLY FAN (SF) SCHEDULE

NOTE: OWNER SHALL DETERMINE ELECTRICAL PANEL AND CIRCUIT FOR EQUIPMENT POWER.



SCALE: 1/2" = 1'-0"

DRAWING: LIGO-D1002397