


MID AND END STATION "B" CHILLER YARD PLAN
 1/4" = 1'-0"

- NOTES:**
1. FOR LEGENDS, ABBREVIATIONS AND GENERAL NOTES SEE SHEET WA-H-001 AND WA-H-002.
 2. MAINTAIN 6'-0" CLEAR HEIGHT UNDER PIPES. FOR PIPE SUPPORT DETAILS SEE STRUCTURAL DRAWING WA-S-401.
 3. PROVIDE FLOOR MOUNTED FLOW SUPPORT AT THE PUMP SUCTION. CONTRACTOR MAY USE SUCTION DIFFUSER/STRAINER.
 4. REFER TO SPECIFICATIONS FOR PIPE SUPPORT REQUIREMENTS.
 5. SUPPORT PIPING TO ELIMINATE ANY LOADS TRANSMITTED FROM PIPING TO PUMPS AND CHILLERS.
 6. FOR PIPING FLOW DIAGRAM SEE SHEET WA-H-201.
 7. FOR CHILLERS AND PUMPS PIPING DETAILS SET SHEETS WA-H-411 AND WA-H-412.
 8. FOR EXACT LOCATION OF THE CHILLERS AND PUMPS SEE CIVIL DRAWINGS.



KEY PLAN
 0 4 8 12 FEET
 1/4" = 1'-0"

This document and the design it covers are the property of PARSONS. It is to be used only for the project and site identified herein. Any other use without the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any way without the written consent from PARSONS.

NO.	DATE	BY	CHKD	ENGR	PROJ	DESCRIPTION
A	4-19-96	CLP	ME	AA	3430GH	FINAL DESIGN REVIEW & BID

DRAWN	CLP
CHECKED	ENGINEER
PROJ	

PARSONS
 100 WEST WALNUT STREET
 PASADENA, CALIFORNIA

LIGO
 CALIFORNIA INSTITUTE OF TECHNOLOGY
 MASSACHUSETTS INSTITUTE OF TECHNOLOGY

LASER INTERFEROMETER
 GRAVITATIONAL-WAVE OBSERVATORY
 SITE NO. 1 - HANFORD, WASHINGTON

TITLE: HVAC
 MID & END STATIONS "B"
 CHILLER YARD PLAN

AS NOTED PPI50969 8094
WA-H-214