

LIGHTING FIXTURE SCHEDULE

Table with columns: FIXTURE TYPE, DESCRIPTION, MANUFACTURER AND CAT. NO., LAMP DATA/BALLAST (TYPE, NOMINAL WATTS, VOLTS). Includes items like 277V 400W METAL HALIDE RECESSED MOUNTED FIXTURE, 277V 400W METAL HALIDE PENDANT MOUNTED FIXTURE, 120V 75W INCANDESCENT FIXTURE, etc.

LIGHTING FIXTURE SCHEDULE

Table with columns: FIXTURE TYPE, DESCRIPTION, MANUFACTURER AND CAT. NO., LAMP DATA/BALLAST (TYPE, NOMINAL WATTS, VOLTS). Includes items like 120V LINE VOLTAGE TYPE, SINGLE CIRCUIT, TRACK LIGHTING FIXTURE, 277V FLUORESCENT FIXTURE, PARABOLIC, 18-CELLER RECESSED MOUNTED, etc.

RECEPTACLE SCHEDULE

Table with columns: RECEPT TYPE, DESCRIPTION, MANUFACTURER, RECEPT CAT. NO., PLUG CAT. NO. Includes items like DUPLEX RECEPTACLE, 20A, 125VAC, 3W, 2P, NEMA 5-20P, STRAIGHT BLADE, etc.

Table with columns: MULTI-CONDUCTOR CABLE POWER & CONTROL, TYPE, HOUSTON CATALOG NUMBER (SEE NOTE 3), O.D. (IN), VOLTAGE INSULATION. Includes items like 5/8"x1/4", 1/2"x1/4", 1/2"x1/4", etc.

Table with columns: MULTI-PAIR CABLE INSTRUMENTATION, TYPE, HOUSTON CATALOG NUMBER (SEE NOTE 3), O.D. (IN), VOLTAGE INSULATION. Includes items like 1-40R18, P-OS (8K, R), 1-80R18, P-OS (8K, R), etc.

SWITCH SCHEDULE

Table with columns: SW. TYPE, DESCRIPTION, MANUFACTURER AND CAT. NO. Includes items like SWITCH, SINGLE POLE, 20A, 277 VAC, TOGGLE TYPE, IVORY, LIGHTED WITH GROUND SCREW, etc.

PLATE SCHEDULE

Table with columns: PLATE TYPE, DESCRIPTION, MANUFACTURER AND CAT. NO. Includes items like SWITCH PLATE, 1-GANG, 1-TOGGLE SWITCH STANDARD SIZE, BRUSHED STAINLESS STEEL, etc.

GENERAL NOTES:

- 1. MULTI-CONDUCTOR CABLES SHALL BE MOISTURE AND HEAT RESISTANT THERMOPLASTIC 75°C, SUITABLE FOR DRY AND WET LOCATIONS, INSULATION CODE THRU NO. 12 AWG AND LARGE WITH GROUNDING GREEN WIRE UNLESS OTHERWISE NOTED.
2. ALL FLUORESCENT FIXTURES SHALL HAVE MAGNETIC ENERGY SAVING BALLASTS 277 VAC, WITH NORMAL LIGHT OUTPUT, RAPID-START, MAGNETIC T1.2, 50°F MINIMUM STARTING TEMPERATURE (T0M1).
3. CATALOG NUMBERS AND VENDOR DESIGNATIONS ARE FOR REFERENCE ONLY. SUBSTITUTION MAY BE MADE WITH AN EQUAL, UPON ELECTRICAL ENGINEERS APPROVAL.
4. ALL METAL HALIDE LAMPS SHALL BE PHOSPHOR-COATED.

NOTES:

- 1. CONTRACTOR SHALL FURNISH AND INSTALL PHOTOELECTRIC CONTROL CELL, LOCKING-TYPE, 1000-1800 W (TUNGSTEN IODIDE BALLAST), 120/277 V, FISHER PIERCE MODEL NO. 779033 (OR EQUAL).

This document and the design it covers are the property of PARSONS. There are no loans only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by the written consent from PARSONS to the borrower.

LIGO-D960392-01-0

LASER INTERFEROMETER GRAVITATIONAL-WAVE OBSERVATORY SITE NO. 1 - HANFORD, WASHINGTON

Table with columns: NO., DATE, BY, CHKD, ENGR, PROJ, DESCRIPTION. Includes entries for 1, 6-15-98, J.G., etc.

AS-BUILT DRAWINGS

PARSONS 100 WEST WALNUT STREET PASADENA, CALIFORNIA

LIGO CALIFORNIA INSTITUTE OF TECHNOLOGY MASSACHUSETTS INSTITUTE OF TECHNOLOGY

Table with columns: ELECTRICAL SCHEDULES MATERIAL, NONE, PPI50969, 8094, WA-E-007