

LIGHTING FIXTURE SCHEDULE

Table with columns: FIXTURE TYPE, DESCRIPTION, MANUFACTURER AND CAT NO., LAMP DATA/BALLAST. Includes items like 277V 400W METAL HALIDE RECESSED MOUNTED FIXTURE, 120V 175W INCANDESCENT FIXTURE, 277V 20W HIGH PRESSURE SODIUM PRISMATIC LENS, etc.

LIGHTING FIXTURE SCHEDULE

Table with columns: FIXTURE TYPE, DESCRIPTION, MANUFACTURER AND CAT NO., LAMP DATA/BALLAST. Includes items like 120V LINE VOLTAGE TYPE SINGLE CIRCUIT TRACK LIGHTING FIXTURE, 277V FLUORESCENT FIXTURE PARABOLIC, 18-CELLS RECESSED MOUNTED, etc.

RECEPTACLE SCHEDULE

Table with columns: RECEPT TYPE, DESCRIPTION, MANUFACTURER. Includes items like DUPLEX RECEPTACLE, 20A 125VAC, 2W 2P, NEMA 5-20P, STRAIGHT BLADE 170V INDUSTRIAL SPECIFICATION GRADE.

Table with columns: MULTI-CONDUCTOR CABLE POWER & CONTROL, TYPE, HOUSTON CATALOG NUMBER, O.D. (IN), VOLTAGE INSULATION. Includes items like 5/8" x 14, 7/8" x 14, 1 1/8" x 14, etc.

Table with columns: MULTI-PAIR CABLE INSTRUMENTATION, TYPE, HOUSTON CATALOG NUMBER, O.D. (IN), VOLTAGE INSULATION. Includes items like 1-49P x 16, P-05 (BK, R), 1-89P x 16, P-05 (BK, R), etc.

SWITCH SCHEDULE

Table with columns: SW. TYPE, DESCRIPTION, MANUFACTURER AND CAT NO. Includes items like SWITCH, SINGLE POLE, 20A, 277 VAC, TOGGLE TYPE, 170V, LIGHTED WITH GROUND SCREW, INDUSTRIAL SPECIFICATION GRADE.

PLATE SCHEDULE

Table with columns: PLATE TYPE, DESCRIPTION, MANUFACTURER AND CAT NO. Includes items like SWITCH PLATE, 1-GANG, 1-TOGGLE SWITCH STANDARD SIZE, BRUSHED STAINLESS STEEL.

GENERAL NOTES:
1. MULTI-CONDUCTOR CABLES SHALL BE MOISTURE AND HEAT RESISTANT THERMOPLASTIC 75°C, SUITABLE FOR DRY AND WET LOCATIONS, INSULATION CODE THRU NO. 12 AWG AND LARGER WITH GROUNDING GREEN WIRE UNLESS OTHERWISE NOTED.
2. ALL FLUORESCENT FIXTURES SHALL HAVE MAGNETIC ENERGY SAVING BALLASTS 277 VAC, WITH NORMAL LIGHT OUTPUT, RAPID-START, MAGNETIC 112, 50°F MINIMUM STARTING TEMPERATURE (LOW).
3. CATALOG NUMBERS AND VENDOR DESIGNATIONS ARE FOR REFERENCE ONLY. SUBSTITUTION MAY BE MADE WITH AN EQUIVALENT, UPON ELECTRICAL ENGINEER'S APPROVAL.
4. ALL METAL HALIDE LAMPS SHALL BE PHOSPHOR-COATED.

NOTES:
1. CONTRACTOR SHALL FURNISH AND INSTALL PHOTOELECTRIC CONTROL CELL, LOCKING-TYPE, 1000-1800 W. FLUORESCENT BALLASTS, 120-277 V, FISHER PIERCE MODEL NO. 1790555 (OR EQUAL).

This document and the design it covers are the property of PARSONS. It is to be used only for the project and site for which it was prepared. It is not to be reproduced, copied, loaned, exhibited, or used in any other way without the written consent of PARSONS. To the contrary.

This document and the design it covers are the property of PARSONS. It is to be used only for the project and site for which it was prepared. It is not to be reproduced, copied, loaned, exhibited, or used in any other way without the written agreement that they will be reproduced, copied, loaned, exhibited, or used in any other way without the written consent of PARSONS. To the contrary.

Table with columns: DRAWN, CHECKED, ENGINEER, PROJ. Includes initials J.G.

PARSONS LIGO CALIFORNIA INSTITUTE OF TECHNOLOGY MASSACHUSETTS INSTITUTE OF TECHNOLOGY
100 WEST WALNUT STREET PASADENA, CALIFORNIA

LASER INTERFEROMETER GRAVITATIONAL-WAVE OBSERVATORY SITE NO. 1 - HANFORD, WASHINGTON
ELECTRICAL SCHEDULES MATERIAL WA-E-007

Table with columns: NO., DESCRIPTION, DATE, BY, CHKD, ENGR, PROJ. Includes drawing information for drawing no. 10-19-94 and 10-31-95.