SCHEMATIC & WIRING DIAGRAM SYMBOLS

- WIRING BY VENDOR
- CALLOUT LEADER
- WIRING BY FIELD
- MECHANICAL INTERLOCK, EXISTING, OR FUTURE AS INDICATED
- WIRING BY OTHERS . IDENTITY OF OTHERS SHALL BE SHOWN EACH TIME THIS SYMBOL IS USED
- ENCLOSURE BOUNDARY
- CROSSING OF CONDUCTORS, NOT CONNECTED
- CONNECTION OF CONDUCTORS
- BREAK IN LINE FOR DRAFTING CLARITY
- CONDUCTORS WITH SHIELD, SHOWN WITH CRIMP LUG INSULATED FROM GROUND
- GROUND
- 1 2 3 — GROUPING OF CONDUCTORS. NUMBERS INDICATE WIRE OR TERMINAL DESIGNATION.
- CONTACT, NORMALLY OPEN (N.O.), FORM 'A' CONTACT. CLOSES WHEN COIL IS ENERGIZED. IDENTIFICATION SAME AS ELECTRICAL DEVICE IN PLAN SYMBOLS
- CONTACT, NORMALLY CLOSED (N.C.), FORM 'B' CONTACT OPENS WHEN COIL IS ENERGIZED
  - O.L. = OVERLOAD RELAY CONTACTS
  - G.R. = GROUND RELAY CONTACTS
- SEPARABLE OR DRAWOUT TYPE CONNECTOR
- EQUIPMENT TERMINAL AND/OR SWITCH CONTACT
- FIELD CONNECTION TO EQUIPMENT TERMINAL
- TERMINATION IN HVAC RELAY BOX
- WIRE CONNECTION, CRIMP TYPE
- TERMINAL OR TERMINAL BOX IN MCC OR SWITCHGEAR
- TERMINAL IN RELAY PANEL
- TERMINAL IN FIELD TERMINAL BOX
- TERMINAL IN MARSHALLING BOX
- TERMINAL IN CONTROL PANEL
- PLC INPUT TERMINAL
- PLC OUTPUT TERMINAL
- TERMINAL IN PACKAGED EQUIPMENT
- M 3 — RELAY COIL :
  - AX = AUXILIARY RELAY.
  - CR = CONTROL RELAY.
  - IR = INTERPOSING RELAY.
  - C = CONTACTOR
  - M = MOTOR STARTER.
  - GR = GROUND RELAY.
  - IC = INSTANTANEOUS CLOSE.
  - IO = INSTANTANEOUS OPEN.
  - SR = REDUCED VOLTAGE STARTING RELAY.
  - TE = TIME DELAY ON ENERGIZATION.
  - TD = TIME DELAY ON DEENERGIZATION.
  - UV = UNDER VOLTAGE.
  - 3 = NUMBER OF CONTACTS.
- A — LIGHTS :
  - A = AMBER LIGHT.
  - B = BLUE LIGHT.
  - C = CLEAR LIGHT.
  - W = WHITE LIGHT.
  - O = ORANGE LIGHT.
  - G = GREEN LIGHT. SWITCH OR CONTACT OPEN, PROCESS ON/VALVE OPEN.
  - R = RED LIGHT. SWITCH OR CONTACT CLOSED, PROCESS OFF/VALVE CLOSED.

SCHEMATIC & WIRING DIAGRAM SYMBOLS

- A — METERS :
  - A = AMMETER.
  - F = FREQUENCY METER.
  - D = DEMAND ATTACHMENT.
  - ET = ELAPSED TIME.
  - GD = GROUND DETECTOR.
  - O = OHM METER.
  - K = KILO PREFIX.
  - M = MEGA PREFIX.
  - PF = POWER FACTOR METER.
  - PH = PHASE ANGLE METER.
  - PI = POSITION INDICATOR.
  - R = RECORDING METER.
  - SY = SYNCHROSCOPE.
  - T = TOTALIZING.
  - TT = TOTAL TIME.
  - V = VOLT METER.
  - VAR = VOLT AMPS REACTIVE.
  - W = WATT.
  - WH = WATT HOUR.
- HHL 27 — DEVICE AS IDENTIFIED ON PROCESS DIAGRAM HIGH-HIGH LEVEL SWITCH NO. 27 SHOWN.
- PUSHBUTTON, NORMALLY OPEN, SINGLE POLE, SINGLE THROW (SPST), MOMENTARY CLOSED
- PUSHBUTTON, NORMALLY CLOSED, SINGLE POLE, SINGLE THROW (SPST), MOMENTARY OPEN.
- H O A — SWITCH, MULTIPLE POLE, MULTIPLE THROW.
  - H = HAND
  - O = OFF
  - A = AUTO
  - X = SWITCH DEVELOPMENT CONTACT MAKE.
  - R = REMOTE
  - L = LOCAL
- TWO-SINGLE CIRCUIT, PUSHBUTTON STATION, SINGLE POLE, SINGLE THROW (SPST), MAINTAINED CONTACT.
- SWITCH, SINGLE POLE, SINGLE THROW (SPST). THE SWITCH BLADE SHALL BE SHOWN ON THE MAINTAINED CONTACT LOAD SIDE (TYPICAL).
- SWITCH, SINGLE POLE, DOUBLE THROW (SPDT) MAINTAINED CONTACT.
- TRANSFER CONTACTS (ALTERNATE TO SPDT).
- ROPE SWITCH, (EMERGENCY STOP).
- LIMIT SWITCH, NORMALLY OPEN (N.O.).
- LIMIT SWITCH, NORMALLY CLOSED (N.C.).
- LEVEL SWITCH - OPENS ON LOW LEVEL, CLOSES ON RISING LEVEL. NORMALLY OPEN (N.O.).
- LEVEL SWITCH - OPENS ON RISING LEVEL, CLOSES ON LOW LEVEL. NORMALLY CLOSED (N.C.).
- PRESSURE SWITCH, FORM "C" CONTACTS. TOP NORMALLY OPEN (N.O.), BOTTOM NORMALLY CLOSED (N.C.).
- PRESSURE SWITCH, OPENS ON HIGH PRESSURE, CLOSES ON LOW PRESSURE. NORMALLY CLOSED (N.C.).
- TEMPERATURE SWITCH, OPENS ON LOW TEMPERATURE, CLOSES ON RISING TEMPERATURE. NORMALLY OPEN (N.O.).
- TEMPERATURE SWITCH, OPENS ON RISING TEMPERATURE, CLOSES ON LOW TEMPERATURE. NORMALLY CLOSED (N.C.).
- VIBRATION SWITCH, OPENS ON VIBRATION. NORMALLY CLOSED (N.C.).
- FLOW SWITCH, OPENS ON DECREASING FLOW, CLOSES ON INCREASING FLOW. NORMALLY OPEN (N.O.).
- FLOW SWITCH, OPENS ON INCREASING FLOW, CLOSES ON DECREASING FLOW. NORMALLY CLOSED (N.C.).
- TE TDC — ON DELAY RELAY CONTACT. NORMALLY OPEN, CLOSES AFTER TIME DELAY (TDC).
- TE TDO — ON DELAY RELAY CONTACT. NORMALLY CLOSED, OPENS AFTER TIME DELAY (TDO).
- IC TDO — OFF DELAY RELAY CONTACT NORMALLY OPEN (N.O.) INSTANTANEOUS CLOSED, OPENS AFTER TIME DELAY (TDO).
- IO TDC — OFF DELAY RELAY CONTACT NORMALLY CLOSED (N.C.) INSTANTANEOUS OPEN, CLOSES AFTER TIME DELAY (TDC).

SCHEMATIC & WIRING DIAGRAM SYMBOLS

- H — ANNUNCIATOR: H=HORN, S=SPEAKER.
- BELL.
- BUZZER.
- S — SOLENOID OPERATED VALVE. (DC COIL REVERSE POLARITY DIODE)
- THERMOCOUPLE
- DIODE
- THYRISTOR
- IN LINE CONDUCTOR CURRENT LIMITING CABLE PROTECTOR
- LIGHTNING OR SURGE ARRESTOR
- PROTECTIVE GAP
- BATTERY
- R1 — RESISTOR R1, 2, 3... = RESISTOR NUMBER.
- ADJUSTABLE OR VARIABLE FUNCTION.
- CARTRIDGE FUSE
  - A = ALARM CONTACT.
  - CL = CURRENT LIMITING.
  - I = INDICATING.
- C1 — CAPACITOR. C1, 2, 3 ... = CAPACITOR NUMBER.
- FUSIBLE LINK.
- CIRCUIT BREAKER, MOLDED CASE
- INDUCTOR
- 480V / 120V 50 VA — CONTROL POWER TRANSFORMER. PRIMARY AND SECONDARY VOLTAGE PLUS VOLT AMPERES SHALL BE SHOWN.
- IDENTIFIED EQUIPMENT.
- TB-A 1 2 3 4 5 6 7 — TERMINAL BLOCK (TB). A, B, C ...ETC = SEQUENTIAL IDENTIFIER. 1, 2, 3 ...ETC = TERMINAL NUMBER.
- △ DENOTES CONTROL DEVICE TO BE LOCATED IN FIELD OR ADJACENT TO MOTOR.
- ▲ LOCATED ON CONTROL BOARD.
- ○ PURCHASED BY INSTRUMENT SPECIFICATION OR REQUISITION.
- ⊗ FURNISHED WITH MECHANICAL EQUIPMENT.

MOTOR CONTROL CABLE CONDUCTOR COLOR CODE

CODE	COLOR	CONDUCTOR NO.
R	RED	1
O	ORANGE	2
X2	WHITE	X2
BU	BLUE	3
Y	YELLOW	4
BK	BLACK	5
BR	BROWN	6
R/BK	RED/BLACK	7
BU/BK	BLUE/BLACK	8
GR	GREEN	GROUND OR (-)

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

LIGO-D960996-01-O

REFERENCES	
LA-E-001	ABBREVIATIONS & ACRONYMS
LA-E-002	STANDARD PLAN SYMBOLS
LA-E-004	ONE/THREE LINE DIAGRAM SYMBOLS
DRAWING NO.	DESCRIPTION

REVISIONS						
NO.	DATE	BY	CHKD	ENGR	PROJ	DESCRIPTION
1	8-7-98	JE				ISSUED FOR AS-BUILT

ISSUED FOR CONSTRUCTION		
DRAWN	M. M.	11-15-96
CHECKED	JCL	7-24-96
ENGINEER	KCR	10-25-96
PROJ	T. D. M.	11-15-96

AS-BUILT DRAWINGS

PARSONS
100 WEST WALNUT STREET
PASADENA, CALIFORNIA

LIGO
CALIFORNIA INSTITUTE OF TECHNOLOGY
MASSACHUSETTS INSTITUTE OF TECHNOLOGY

LASER INTERFEROMETER
GRAVITATIONAL-WAVE OBSERVATORY
SITE NO.2 - LIVINGSTON, LOUISIANA

TITLE: ELECTRICAL STANDARD SCHEMATIC & WIRING DIAGRAMS SYMBOLS

SCALE: NONE | CONTRACT NUMBER: PP150969 | PROJECT NUMBER: 8094

SHEET NUMBER: LA-E-003 | REVISIONS: 1

LIGOLAF.BDR

Wed Oct 7 09:21:58 1998 c:\plot\qcf\S3-3B.qcf N:\DUELUES\E3DB2\EE003.PMF