

PANEL 175RP_1		LOCATION RM 175										VOLTS 208Y/120V				
FED FROM	CKT #	MOUNTING RECESSED										MAIN				
		PHASE 3	WIRE 4	FEEDER		BUS 100										
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	MISC RM 175	1	3		20	7203	2401			1920	20		1	2	MISC RM 175	2
		3					2401			1920	20		1	4	MISC RM 175	4
		5					2401			1920	20		1	6	MISC RM 175	6
7	MISC RM 175	7	3		20	7203	2401			1920	20		1	8	MISC RM 175	8
		9					2401			1920	20		1	10	MISC RM 175	10
		11					2401			1920	20		1	12	MISC RM 175	12
13	MISC RM 175	13	1		20	1920	1920						14	SPACE	14	
15	MISC RM 175	15	1		20	1920		1920					16	SPACE	16	
17	MISC RM 175	17	1		20	1920			1920				18	SPACE	18	
19	SPACE	19											20	SPACE	20	
21	SPACE	21											22	SPACE	22	
23	SPACE	23											24	SPACE	24	
25	SPACE	25											26	SPACE	26	
27	SPACE	27											28	SPACE	28	
29	SPACE	29											30	SPACE	30	
TOTAL							8161	8161	8161							
TOTAL CONNECTED LOAD (VA)							24483									
TOTAL CONNECTED LOAD (AMPS)							67.95									

PANEL 175RP_2		LOCATION RM 175										VOLTS 208Y/120V				
FED FROM	CKT #	MOUNTING RECESSED										MAIN				
		PHASE 3	WIRE 4	FEEDER		BUS 100										
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	MISC RM 175	1	3		20	7203	2401			1920	20		1	2	MISC RM 175	2
		3					2401			1920	20		1	4	MISC RM 175	4
		5					2401			1920	20		1	6	MISC RM 175	6
7	MISC RM 175	7	3		20	7203	2401			1920	20		1	8	MISC RM 175	8
		9					2401			1920	20		1	10	MISC RM 175	10
		11					2401			1920	20		1	12	MISC RM 175	12
13	MISC RM 175	13	1		20	1920	1920						14	SPACE	14	
15	MISC RM 175	15	1		20	1920		1920					16	SPACE	16	
17	MISC RM 175	17	1		20	1920			1920				18	SPACE	18	
19	SPACE	19											20	SPACE	20	
21	SPACE	21											22	SPACE	22	
23	SPACE	23											24	SPACE	24	
25	SPACE	25											26	SPACE	26	
27	SPACE	27											28	SPACE	28	
29	SPACE	29											30	SPACE	30	
TOTAL							8161	8161	8161							
TOTAL CONNECTED LOAD (VA)							24483									
TOTAL CONNECTED LOAD (AMPS)							67.95									

not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will

NO.	DATE	BY	CHKD	ENGR	PROJ	DESCRIPTION
1	6-15-98	J.G.				ISSUED FOR AS-BUILT

ISSUED FOR CONSTRUCTION		
DRAWN	M.M.	6-25-96
CHECKED	J.K.	7-3-96
ENGINEER	K.R.	7-3-96
PROJ	M.D.W.	7-8-96
AS-BUILT DRAWINGS		


PARSONS
 100 WEST WALNUT STREET
 PASADENA, CALIFORNIA


 CALIFORNIA INSTITUTE OF TECHNOLOGY
 MASSACHUSETTS INSTITUTE OF TECHNOLOGY

LIGO-D961201-01-O

LASER INTERFEROMETER
 GRAVITATIONAL-WAVE OBSERVATORY
 SITE NO. 1 - HANFORD, WASHINGTON

TITLE	SCALE	CONTRACT NUMBER	PROJECT NUMBER
ELECTRICAL CORNER STATION LVEA OSB PANEL SCHEDULES	NONE	PP150969	8094
SHEET NUMBER		REVISIONS	
WA-E-122			