

PANEL 175RP_1		LOCATION RM 175										VOLTS 208Y/120V				
FED FROM	CKT #	MOUNTING RECESSED										MAIN				
		PHASE 3	WIRE 4	FEEDER				BUS 100								
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	MISC RM 175	1	3	20	7203	2401 1920			1920	20		1	2	MISC RM 175	2	
		3							1920	20		1	4	MISC RM 175	4	
		5							1920	20		1	6	MISC RM 175	6	
7	MISC RM 175	7	3	20	7203	2401 1920			1920	20		1	8	MISC RM 175	8	
		9							1920	20		1	10	MISC RM 175	10	
		11							1920	20		1	12	MISC RM 175	12	
13	MISC RM 175	13	1	20	1920	1920							14	SPACE	14	
15	MISC RM 175	15	1	20	1920			1920					16	SPACE	16	
17	MISC RM 175	17	1	20	1920			1920					18	SPACE	18	
19	SPACE	19											20	SPACE	20	
21	SPACE	21											22	SPACE	22	
23	SPACE	23											24	SPACE	24	
25	SPACE	25											26	SPACE	26	
27	SPACE	27											28	SPACE	28	
29	SPACE	29											30	SPACE	30	
TOTAL						8161	8161	8161								
TOTAL CONNECTED LOAD (VA)						24483										
(AMPS)						67.95										

PANEL 175RP_2		LOCATION RM 175										VOLTS 208Y/120V				
FED FROM	CKT #	MOUNTING RECESSED										MAIN				
		PHASE 3	WIRE 4	FEEDER				BUS 100								
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	MISC RM 175	1	3	20	7203	2401 1920			1920	20		1	2	MISC RM 175	2	
		3							1920	20		1	4	MISC RM 175	4	
		5							1920	20		1	6	MISC RM 175	6	
7	MISC RM 175	7	3	20	7203	2401 1920			1920	20		1	8	MISC RM 175	8	
		9							1920	20		1	10	MISC RM 175	10	
		11							1920	20		1	12	MISC RM 175	12	
13	MISC RM 175	13	1	20	1920	1920							14	SPACE	14	
15	MISC RM 175	15	1	20	1920			1920					16	SPACE	16	
17	MISC RM 175	17	1	20	1920			1920					18	SPACE	18	
19	SPACE	19											20	SPACE	20	
21	SPACE	21											22	SPACE	22	
23	SPACE	23											24	SPACE	24	
25	SPACE	25											26	SPACE	26	
27	SPACE	27											28	SPACE	28	
29	SPACE	29											30	SPACE	30	
TOTAL						8161	8161	8161								
TOTAL CONNECTED LOAD (VA)						24483										
(AMPS)						67.95										

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

NO.	DATE	BY	CHKD	ENGR	PROJ	DESCRIPTION
1	6-15-98	J. G.				ISSUED FOR AS-BUILT

ISSUED FOR CONSTRUCTION		
DRAWN	M. M.	6-25-96
CHECKED	J. K.	7-3-96
ENGINEER	K. R.	7-3-96
PROJ	M. D. W.	7-8-96

**AS-BUILT DRAWINGS**



LASER INTERFEROMETER GRAVITATIONAL-WAVE OBSERVATORY SITE NO. 1 - HANFORD, WASHINGTON			
TITLE	ELECTRICAL CORNER STATION LVEA OSB PANEL SCHEDULES	SCALE	NONE
SHEET NUMBER	WA - E - 122	CONTRACT NUMBER	PP150969
PROJECT NUMBER	8094	REVISIONS	

LIGO-D961201-01-O