

REV.	DEO #	DATE	BY:	CHECK
0	0038	1/3/96	D. Moore	D. Moore
1	0052	1/29/96	D. Moore	D. Moore
2	0296	8/20/96	D. Moore	D. Moore

TITLE: Heat Load Calculations
on Clean (No frost) 80K
Pumps from Beam Tube
& Vacuum Chamber

By: David Moore DEPT.: 744

PROJECT: LIGO

PROJECT NO: V59049

PURPOSE: To determine heat loads on long and short pumps in their clean condition due to thermal radiation exchange with the pump vacuum chamber and the beam tube.

METHOD: Radiation network equations.

SUMPTIONS:

1. One radiation shield in the vacuum annulus surrounding the pump LN₂ reservoir.
2. Low emissivity (.06) thermal sleeves in beam tube.
3. Pumps in clean condition.

INPUTS:

REFERENCES:

1. Heat Transfer, J.P. Holman, 3rd ed., McGraw-Hill.
2. Thermal Radiation Heat Transfer, Siegel & Howell, McGraw-Hill

CALCULATIONS: (SEE ATTACHED)


CONCLUSIONS:

Radiation shield temp. = 269.5 K	
Long Pump (clean):	258 watts (from beam tube) 176 watts (from vac. cham.) <u>434 watts Total</u>
Short Pump (clean):	117.0 watts <u>64.0 watts</u> <u>181.0 total</u>


NOTES:



Short Pump
 (No Frost)



Surfaces ② & ⑤
 are fictitious sur-
 faces used to simplify
 view factor calculations



View Factors

$$F_{12} = \frac{d}{x} = \frac{1.13}{0.889} = 1.27$$

$$\therefore F_{12} = 0.25$$

(Heat Transfer, Holman, 3rd ed., pp. 249)

$$F_{13} = 1 - F_{12} = 0.75$$

$$F_{15} = \frac{d}{x} = \frac{1.13}{(0.889 + 1.22)} = 0.54$$

$$F_{15} = 0.07$$

$$\therefore F_{14} = F_{12} - F_{15} = 0.25 - 0.07 = 0.18$$

$$F_{17} = \frac{d}{x} = \frac{1.13}{2(0.889) + 1.22} = 0.38$$

$$F_{17} = 0.04$$

$$F_{76} = F_{13} = 0.75$$

$$F_{41} = \frac{A_1}{A_4} F_{14} = \frac{\pi/4 (1.13)^2}{\pi (1.13)(1.22)} (0.18)$$


$$F_{41} = 0.042$$

$$F_{25} = \frac{d}{x} = \frac{1.12}{1.22} = 0.92$$

$$F_{25} = 0.15$$

$$F_{24} = 1 - F_{25} = 0.85$$

Fig. 8-13 Radiation shape factor for radiation between parallel disks.



$$\begin{aligned}
 F_{42} &= \frac{A_2}{A_4} F_{24} \\
 &= \frac{(\pi/4)(1.13)^2}{\pi(1.13)(1.22)} (.85) \\
 &= 0.197
 \end{aligned}$$

$$\begin{aligned}
 F_{43} &= F_{42} - F_{41} \\
 &= 0.197 - .042 \\
 &= 0.15
 \end{aligned}$$

Surface resistances

$$\begin{aligned}
 \frac{1 - \epsilon_4}{\epsilon_4 A_4} &= \frac{1 - .06}{.06 \pi (1.35)(1.22)} \\
 &= 3.03
 \end{aligned}$$

$$\begin{aligned}
 \frac{1 - \epsilon_3}{\epsilon_3 A_3} &= \frac{1 - 0.06}{.06 \pi (1.13)(.889)} \\
 &= 4.96
 \end{aligned}$$

Geometry resistance:

$$\frac{1}{A_1 F_{14}} = 1 / \left(\frac{\pi}{4} (1.13)^2 (.18) \right) = 5.54$$

$$\frac{1}{A_4 F_{43}} = 1 / \left(\pi (1.13) (1.22) (.15) \right) = 1.54$$

$$\frac{1}{A_1 F_{13}} = 1 / \left(\frac{\pi}{4} (1.13)^2 (.75) \right) = 1.33$$

Sum currents

$$\textcircled{1} \quad \frac{2.3 - J_4}{3.03} + 2 \frac{(460 - J_4)}{5.54} + 2 \frac{(J_3 - J_4)}{1.54} = 0$$

$$(J_3 = J_6)$$

$$\textcircled{3} \quad \frac{460 - J_3}{1.33} + \frac{460 - J_3}{4.96} + \frac{J_4 - J_3}{1.54} = 0$$

From $\textcircled{1}$

$$.759 - .330 J_4 + 166.06 - .36 J_4 + 1.30 J_3 - 1.30 J_4 = 0$$

$$1.30 J_3 - 1.99 J_4 = -166.82$$

From $\textcircled{3}$

$$345.86 - .752 J_3 + 92.74 - .202 J_3 + .650 (J_4 - J_3) = 0$$

$$-1.604 J_3 + .650 J_4 = -438.60$$

$$\begin{matrix} 1.3 & -1.99 \\ -1.604 & 0.65 \end{matrix}$$

matrix

$$\begin{matrix} -166.82 & \text{constants} \\ -438.6 \end{matrix}$$

$$\begin{matrix} -0.27695 & -0.84791 \\ -0.68344 & -0.55391 \end{matrix}$$

inverse

$$J_3 = 418.0928 \text{ solution}$$

$$J_4 = 356.9551$$

$$Q_A = (J_4 - E_{b4}) / \frac{1 - \epsilon_4}{\epsilon_4 A_4}$$

$$= (356.96 - 2.3) / 3.03$$

$$= 117 \text{ watts}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS




V049-1-033

Pg 7 of 23



Long Pump
 (No Frost)



Surfaces ② & ⑤
 are fictitious surfaces
 used to simplify view factor
 calculations.

View Factors:

$$F_{12} = \frac{d}{x} = \frac{1.13}{.889} = 1.27$$

$$\therefore F_{12} = .25 \quad (\text{Heat Transfer, Holman, 3rd ed., pp 299})$$

$$F_{13} = 1 - F_{12} \\ = .75$$

$$F_{15} = \frac{d}{x} = \frac{1.13}{(.889+3.71)} = .245$$

$$F_{15} = 0.03$$

$$\therefore F_{14} = F_{12} - F_{15} \\ = .12 - .03 = .09$$

$$F_{17} = \frac{d}{x} = \frac{1.13}{2(.889)+3.71} = .205 \quad F_{17} = .025$$

$$F_{76} = F_{13} = .75$$

$$F_{41} = \frac{A_1}{A_4} F_{14} = \frac{\pi/4 (1.13)^2}{\pi (1.13)(3.71)} (.09)$$

$$F_{41} = .007$$

$$F_{25} = \frac{d}{x} = \frac{1.13}{3.71} = .30$$

$$F_{25} = .04$$

$$\therefore F_{24} = 1 - F_{25} \\ = .96$$

$$\begin{aligned}
 F_{42} &= \frac{A_2}{A_4} F_{24} \\
 &= \frac{(\pi/4)(1.13)^2}{\pi(1.13)(3.71)} (.96) \\
 &= .073
 \end{aligned}$$

$$\begin{aligned}
 F_{43} &= F_{42} - F_{41} \\
 &= .073 - .007 \\
 &= .066
 \end{aligned}$$

Surface resistances :

$$\begin{aligned}
 \frac{1 - \epsilon_4}{\epsilon_4 A_4} &= \frac{1 - .06}{.06 (\pi)(1.35)(3.71)} \\
 &= 1.00
 \end{aligned}$$

$$\begin{aligned}
 \frac{1 - \epsilon_3}{\epsilon_3 A_3} &= \frac{1 - .06}{.06 (\pi)(1.13)(1.5)} \\
 &= 2.94
 \end{aligned}$$

Geometry resistance :

$$\frac{1}{A_1 F_{14}} = \frac{1}{\frac{\pi}{4} (1.13)^2 (.09)} = 11.08$$

$$\frac{1}{A_4 F_{43}} = \frac{1}{\pi (1.35)(3.71) (.066)} = 0.97$$

$$\frac{1}{A_1 F_{13}} = \frac{1}{\frac{\pi}{4} (1.13)^2 (.75)} = 1.33$$

Sum currents:

$$\textcircled{1} \quad \frac{2.3 - J_4}{1.00} + 2 \frac{(460 - J_4)}{11.08} + 2 \frac{(J_3 - J_4)}{0.97} = 0$$

$$(J_3 = J_6)$$

$$\textcircled{2} \quad \frac{460 - J_3}{1.13} + \frac{460 - J_3}{2.94} + \frac{J_4 - J_3}{0.97} = 0$$

From $\textcircled{1}$

$$2.30 - 1.00 J_4 + 83.03 - .181 J_4 + 2.06 J_3 - 2.06 J_4 = 0$$

$$2.06 J_3 - 3.24 J_4 = -85.33$$

From $\textcircled{2}$

$$407.08 - .885 J_3 + 156.46 - .340 J_3 + 1.03 (J_4 - J_3) = 0$$

$$-2.26 J_3 + 1.03 J_4 = -563.54$$

J3= 367.9882 solution

J4= 260.3042

2.06 -3.24

-2.26 1.03

matrix

-85.33

constants

-563.54

-0.19805 -0.62301

-0.43457 -0.39611

inverse

J3= 367.9882 solution

J4= 260.3042

V049-1-033

Pg 11 of 23

$$\begin{aligned} Q_4 &= (J_4 - E_{b4}) / \frac{1 - \epsilon_4}{\epsilon_4 A_4} \\ &= (260.3 - 2.3) / 1.00 \\ &= 258 \text{ watts} \end{aligned}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



V049-1-033

Page 12 of 23

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS




Pump Radiation Shield Thermal Calculations

V049-1-033

Pg 13 of 23



Short Pump Radiation Shield




$$A_1 = \frac{2\pi(32)(48)}{(39.4)^2} = 6.22 \text{ m}^2$$

$$A_2 = \frac{2\pi(40)(48)}{(39.4)^2} = 7.77 \text{ m}^2$$


$$A_3 = \frac{\pi(40^2 - 32^2)}{(39.4)^2} = 1.17 \text{ m}^2$$

$$A_4 = \frac{2\pi(29.75)(48)}{(39.4)^2} = 5.78 \text{ m}^2$$





Pump Thermal Model with Radiation Shield




V049-1-033

Pump View Factor Shield to Chamber

CATALOG OF SELECTED CONFIGURATION FACTORS 789

(Siegel & Howell)

25



Two concentric cylinders of same finite length.

$$R = \frac{r_2}{r_1} \quad L = \frac{l}{r_1}$$

$$A = L^2 + R^2 - 1$$

$$B = L^2 - R^2 + 1$$

$$F_{2-1} = \frac{1}{R} - \frac{1}{\pi R} \left\{ \cos^{-1} \left(\frac{B}{A} \right) - \frac{1}{2L} \left[\sqrt{(A+2)^2 - (2R)^2} \cos^{-1} \left(\frac{B}{RA} \right) + B \sin^{-1} \left(\frac{1}{R} \right) - \frac{\pi A}{2} \right] \right\}$$

$$F_{2-2} = 1 - \frac{1}{R} + \frac{2}{\pi R} \tan^{-1} \left(\frac{2\sqrt{R^2 - 1}}{L} \right)$$

$$- \frac{L}{2\pi R} \left\{ \frac{\sqrt{4R^2 + L^2}}{L} \sin^{-1} \left[\frac{4(R^2 - 1) + (L^2/R^2)(R^2 - 2)}{L^2 + 4(R^2 - 1)} \right] \right.$$

$$\left. - \sin^{-1} \left(\frac{R^2 - 2}{R^2} \right) + \frac{\pi}{2} \left(\frac{\sqrt{4R^2 + L^2}}{L} - 1 \right) \right\}$$

where for any argument ξ :

$$-\frac{\pi}{2} \leq \sin^{-1} \xi \leq \frac{\pi}{2}$$

$$0 \leq \cos^{-1} \xi \leq \pi$$

Short Pump:

$$R = \frac{40''}{32''} = 1.25$$

$$L = 48/32 = 1.5$$

$$A = 1.5^2 + 1.25^2 - 1 = 2.81$$

$$B = 1.5^2 - 1.25^2 + 1 = 1.69$$

$$\cos^{-1} \left(\frac{B}{A} \right) = .926$$

$$\cos^{-1} \left(\frac{B}{RA} \right) = 1.069$$

$$\sin^{-1} \left(\frac{1}{R} \right) = .927$$

VO49-1-033

Pg 16 of 23

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



$$F_{2-1} = \frac{1}{1.25} - \frac{1}{\pi(1.25)} \left\{ .926 - \frac{1}{2(1.5)} \left[\sqrt{4.81^2 - 2.5^2} \right. \right. \\ \left. \left. \times 1.069 + 1.69(.927) - \frac{\pi(2.81)}{2} \right] \right\}$$

$$F_{2-1} = .695 \quad (\text{Results same for long pump})$$

From view factor algebra

$$A_1 F_{1-2} = A_2 F_{2-1}$$

$$F_{1-2} = \frac{A_2}{A_1} F_{2-1} = \frac{D_2}{D_1} F_{2-1}$$

$$\therefore F_{1-2} = \left(\frac{80}{64} \right) (.695)$$

$$\underline{F_{1-2} = .869}$$

$$F_{2-2} : \tan^{-1} \left(\frac{2\sqrt{1.25^2 - 1}}{1.5} \right) = .7854$$

$$\sin^{-1} \left(\frac{1.25^2 - 2}{1.25^2} \right) = -.284$$

$$\frac{\sqrt{4(1.25)^2 + (1.5)^2}}{1.5} = 1.944$$

$$\sin^{-1} \left(\frac{4(1.25^2 - 1) + \left(\frac{1.5^2}{1.25^2} \right) (1.25^2 - 2)}{1.5^2 + 4(1.25^2 - 1)} \right) = .368$$

$$F_{2-2} = 1 - \frac{1}{1.25} + \frac{2}{\pi(1.25)} (.785)$$

$$- \frac{1.5}{2\pi(1.25)} \left\{ 1.944(.368) - (-.284) + \frac{\pi}{2}(1.302-1) \right\}$$

$$F_{2-2} = .318$$

from view factor algebra

$$F_{2-1} + F_{2-2} + F_{2-3} + F_{2-4} = 1.0$$

$$.695 + .318 + 2F_{2-3} = 1.0 \quad \left(\begin{array}{l} \text{Not exactly} \\ = 1.0 \text{ due to} \\ \text{round-off error} \end{array} \right)$$

$$\therefore F_{2-3} < .01 \quad (\text{Use } .01)$$

$$\nexists F_{2-4} < .01$$

$$\nexists F_{1-2} + F_{1-3} + F_{1-4} = 1.0$$

$$F_{1-2} + 2F_{1-3} = 1.0$$

$$.869 + 2F_{1-3} = 1.0$$

$$F_{1-3} = .0655$$

$$F_{1-4} = .0655$$

$$A_2 F_{2-3} = A_3 F_{3-2}$$

$$F_{3-2} = \left(\frac{7.77}{1.17} \right) (.01) = .066$$

$$A_1 F_{1-3} = A_3 F_{3-1}$$

$$F_{3-1} = \left(\frac{6.22}{1.17} \right) (.0655) = .348$$

$$F_{3-1} + F_{3-2} + F_{3-4} = 1.0$$

$$\therefore F_{3-4} = .586$$

$$\nexists F_{4-3} = .586$$

$$\nexists F_{1-5} \approx 1.0$$



$$E_{b5} = \sigma(80)^4 = 2.3 \text{ w/m}^2$$

$$E_{b2} = E_{b3} = E_{b4} = \sigma(300)^4 = 460 \text{ w/m}^2$$

Unknowns: J_1, J_2, J_3 ; $J_3 = J_4$ by symmetry
 J_6, E_{b6}, J_5

$$\frac{1 - \epsilon_5}{\epsilon_5 A_5} = \frac{1 - .06}{.06(5.78)} = 2.710$$

$$\frac{1 - \epsilon_3}{\epsilon_3 A_3} = \frac{1 - 0.3}{0.3(1.17)} = 1.994$$

$$\frac{1 - \epsilon_2}{\epsilon_2 A_2} = \frac{1 - 0.3}{0.3(7.77)} = 0.300$$

$$\frac{1 - \epsilon_4}{\epsilon_4 A_4} = 1.994$$

$$\frac{1 - \epsilon_6}{\epsilon_6 A_6} = \frac{1 - .06}{.06(6.22)} = 2.519$$

$$\frac{1}{A_1 F_{12}} = \frac{1}{6.22(.869)} = .185$$

$$\frac{1}{A_1 F_{13}} = \frac{1}{6.22(.0655)} = 2.455$$

$$\frac{1}{A_2 F_{24}} = \frac{1}{7.77(.01)} = 12.87$$

$$\frac{1}{A_1 F_{14}} = \frac{1}{6.22(.0655)} = 2.455$$

$$\frac{1}{A_2 F_{23}} = \frac{1}{7.77(.01)} = 12.87$$

$$\frac{1}{A_3 F_{34}} = \frac{1}{1.17(.586)} = 1.459$$

$$\frac{1}{A_1 F_{15}} = \frac{1}{6.22(1.0)} = .1608$$

$$\frac{1}{A_5 F_{56}} = \frac{1}{5.78(1.0)} = .1730$$

Sum the currents into the nodes

$$\textcircled{1} \quad J_1: \quad \frac{E_{b6} - J_1}{2.519} + \frac{J_2 - J_1}{.185} + \frac{J_3 - J_1}{2.455} + \frac{J_4 - J_1}{2.455} = 0 \quad \checkmark$$

$$\textcircled{2} \quad J_2: \quad \frac{J_1 - J_2}{.185} + \frac{460 - J_2}{0.300} + \frac{J_3 - J_2}{12.87} + \frac{J_4 - J_2}{12.87} = 0$$

$$\textcircled{3} \quad J_3: \quad \frac{460 - J_3}{1.994} + \frac{J_1 - J_3}{2.455} + \frac{J_2 - J_3}{12.87} + \frac{J_4 - J_3}{1.459} = 0$$

$$\textcircled{4} \quad J_4: \quad \frac{460 - J_4}{1.994} + \frac{J_2 - J_4}{12.87} + \frac{J_1 - J_4}{2.455} + \frac{J_3 - J_4}{1.459} = 0$$

(not an independent equation)

$$\textcircled{5} \quad J_5: \quad \frac{2.3 - J_5}{2.710} + \frac{J_6 - J_5}{.1730} = 0$$

$$\textcircled{6} \quad J_6: \quad \frac{J_5 - J_6}{.1730} + \frac{E_{b6} - J_6}{2.519} = 0$$

$$\textcircled{7} \quad E_{b6}: \quad \frac{J_6 - E_{b6}}{2.519} + \frac{J_1 - E_{b6}}{2.519} = 0$$

$$\text{From } \textcircled{1} \quad .397E_{b6} - .397J_1 + 5.405J_2 - 5.405J_1 + .107J_3 - .407J_1 \\ + .407J_3 - .407J_1 = 0$$

$$.397E_{b6} = 6.618J_1 + 5.405J_2 + .814J_3 = 0$$

$$\text{From } \textcircled{2} \quad 5.405J_1 - 5.405J_2 + 1533.33 - 3.333J_2 + .0777J_3$$

$$- .0777J_2 + .0777J_3 - .0777J_2 = 0$$

$$5.405J_1 - 8.893J_2 + .1554J_3 = -1533.33$$

$$\text{From } \textcircled{3} \quad 230.692 - .502J_3 + .407J_1 - .407J_3$$

$$+ .0777J_2 - .0777J_3 = 0$$

$$.407J_1 + .0777J_2 - .987J_3 = -230.692$$

$$\begin{aligned} \text{From } \textcircled{5} \quad .849 - .369 J_5 + 5.78 J_6 - 5.78 J_5 &= 0 \\ -6.149 J_5 + 5.78 J_6 &= -.849 \end{aligned}$$

$$\begin{aligned} \text{From } \textcircled{4} \quad 5.78 J_5 - 5.78 J_6 + .397 E_{b6} - .397 J_6 &= 0 \\ 5.78 J_5 - 6.177 J_6 + .397 E_{b6} &= 0 \end{aligned}$$

$$\begin{aligned} \text{From } \textcircled{7} \quad .397 J_6 - .397 E_{b6} + .397 J_1 - .397 E_{b6} &= 0 \\ .397 J_1 + .397 J_6 - .794 E_{b6} &= 0 \end{aligned}$$

$$\begin{bmatrix} -6.618 & 5.405 & .814 & 0 & 0 & .397 \\ 5.405 & -8.893 & .1554 & 0 & 0 & 0 \\ .407 & .0777 & -.987 & 0 & 0 & 0 \\ 0 & 0 & 0 & -6.149 & 5.78 & 0 \\ 0 & 0 & 0 & 5.78 & -6.177 & .397 \\ .397 & 0 & 0 & 0 & .397 & -.794 \end{bmatrix} \begin{bmatrix} J_1 \\ J_2 \\ J_3 \\ J_5 \\ J_6 \\ E_{b6} \end{bmatrix} = \begin{bmatrix} 0 \\ -1533 \\ -230.692 \\ -.849 \\ 0 \\ 0 \end{bmatrix}$$

-6.618	5.405	0.814	0	0	0.397	0
5.405	-8.893	0.1554	0	0	0	-1533.33
0.407	0.0777	-0.987	0	0	0	-230.692
0	0	0	-6.149	5.78	0	-0.849
0	0	0	5.78	-6.177	0.397	0
0.397	0	0	0	0.397	-0.794	0

-0.37828	-0.23296	-0.34865	-0.12942	-0.137687	-0.25798	
-0.23296	-0.25607	-0.23244	-0.0797	-0.084793	-0.15888	
-0.17433	-0.11622	-1.17524	-0.05964	-0.063452	-0.11889	
-0.12942	-0.0797	-0.11929	-1.8271	-1.770734	-0.95008	
-0.13769	-0.08479	-0.1269	-1.77073	-1.883779	-1.01073	
-0.25798	-0.15888	-0.23778	-0.95008	-1.010733	-1.8938	

(Matrix inversion)

solution

J1= 437.7435
 J2= 446.3248
 J3= 449.3749
 J5= 151.283
 J6= 160.7942
 Eb6= 299.2688

∴ Heat load on pump reservoir is:

$$\frac{J_5 - E_{b5}}{\left(\frac{1 - \epsilon_5}{\epsilon_5 A_5}\right)} = \frac{151.28 - 2.3}{2.71}$$

$$= 55 \text{ watts}$$

For long pump the load may be scaled up by the length ratios to give a good approximation

∴ $Q_{\text{pump}}^{\text{long}} = 55 \left(\frac{146''}{48''}\right)$
 $= 167 \text{ watts}$

Shield temp = $\left(\frac{299.27}{5.67 \times 10^{-8}}\right)^{1/4} = 269.5 \text{ K}$

Calculation of Heat Load From Ends of 80K Pump *

For floating shield, the temperature of the shield was calculated from the computer model of the single pump shield as 269.5 K

$$\begin{aligned}
 \text{Area of ends: } A &= \frac{\pi}{4} (D_o^2 - D_i^2) \times 2 \text{ ends} \\
 &= \frac{\pi}{4} (57.5^2 - 53^2) \times 2 \times 6.45 \\
 &= 5038 \text{ cm}^2
 \end{aligned}$$

$$\begin{aligned}
 Q &= \sigma A \epsilon F (T_1^4 - T_2^4) \\
 &= (5.67 \times 10^{-12}) (5038) (.06) ((269.5)^4 - (80)^4) \\
 &= \underline{19.0 \text{ watts}}
 \end{aligned}$$

* Ends of pump LN₂ reservoir are shielded from pump vacuum chamber.

REV.	DEO #	DATE	BY:	CHECK
0	0041	1/9/96	D. Moore	D. Moore
1	0056	1/30/96	D. Moore	D. Moore

TITLE: Steady State LN₂ Pump Requirements for 80K Pump and Two Phase Flow Regime Calculations for Supply Line

By: David Moore DEPT.: 744

PROJECT: LIGO

PROJECT NO: V59049

PURPOSE: To determine LN₂ consumption for 80K pump & determine supply line size / two phase flow regime

METHOD: Standard methods on a spreadsheet and use of published charts for two phase flow.

SUMPTIONS: Steady state conditions

INPUTS: Heat flux calculations

- REFERENCES:
1. LIGO doc. # V049-1-033
 2. Published charts for two phase flow in vertical & horizontal pipes
 3. Nitrogen properties from GASPAC (see pg. 8)

CALCULATIONS: (SEE ATTACHED)

- CONCLUSIONS:
1. Short pump consumption: range = .0224 - .0614 gpm
 2. Long pump consumption: range = .0479 - .0781 gpm
 3. Use 1/2" pipe for supply line. Slug flow unavoidable if supply line downstream of control valve is vertical.

NOTES:

LN2 Requirements for
80K pumps

1/30/96

Heat Load Summary
(watts)

	Short Pump Clean	Short Pump Frosted	Long Pump Clean	Long Pump Frosted
Beam Tube Load	116	499	249	546
Vac. chamber	64	64	176	176
Supports (est.)	9	9	14	14
Pump subtotal	189	572	439	736
VJ pipe (55')	6.06	6.06	6.06	6.06
Valves (3)	12.1	12.1	12.1	12.1
Bayonets	12.39	12.39	12.39	12.39
Supply line subtotal	30.55	30.55	30.55	30.55
Pump & supply line total (watts)	219.55	602.55	469.55	766.55
LN2 Consump. (gpm)				
-pump	0.01926359	0.05830038	0.04474453	0.0750159
-supply line	0.00311377	0.00311377	0.00311377	0.0031138
Total (gpm)	0.02237736	0.06141416	0.0478583	0.0781297

88g/day

112g/day

V049-1-037

Pg 2 of 7

LIGO 80K Pump

1/30/96

Flow Regime in
supply line

```

+-----+
|Two Phase Flow|
|Horizontal pipe|
+-----+

```

Pipe dia. 1/2 in. 0.0562 ft.

		Long pump Clean	Long Pump Frosted	Short Pump Clean	Short Pump Frosted
Transf. line					
heat leak	watts	30.55	30.55	30.55	30.55
Pump heat leak	watts	439	736	189	736
Total heat leak	watts	469.55	766.55	219.55	766.55
Mixture quality		0.11970043	0.09493444	0.19248617	0.10559136
Liquid Flow Rate	gpm	0.0478583	0.0781297	0.02237736	0.06141416
Liquid Flow Rate	lb/min.	0.3206762	0.52351077	0.14994028	0.41150771
Vapor Flow Rate	lb/min.	0.03838508	0.0496992	0.02886143	0.04345166
Liquid density	lb/ft**3	50.12	50.12	50.12	50.12
Vapor density	lb/ft**3	0.3293	0.3293	0.3293	0.3293
Surface tension	dyne/cm	12.26	12.26	12.26	12.26
Liquid viscosity	cp	0.1449	0.1449	0.1449	0.1449
Mixture velocity	ft/sec	0.82636998	1.08446858	0.60911571	0.94194922
Lambda(flow param.)		1.87943254	1.87943254	1.87943254	1.87943254
Psi(flow param.)		1.100466	1.100466	1.100466	1.100466
Pipe area	ft**2	0.00248	0.00248	0.00248	0.00248
Gf(flow/unit area)	lb/hr				
	-ft**2	7758.29523	12665.5832	3627.58738	9955.83179
Gg(flow/unit area)	lb/hr				
	-ft**2	928.67129	1202.4	698.260403	1051.24984
Gg/lambda		494.123237	639.767576	371.52725	559.344279
Gf(lambda)(Psi)/Gg		17.2785643	21.7861051	10.7449362	19.5873182
Flow Regime		stratified	stratified	stratified	stratified

V049-1-037

Pg 3 of 7

+-----+
|Two Phase Flow|
|Vertical pipe |
+-----+

Volumetric gas fraction	Fv	0.94796708	0.93527163	0.96699312	0.94142174
Froude No.	NFr	0.37783024	0.65070118	0.20528029	0.49091084
Flow Regime		slug	slug	slug	slug

The boundaries between flow regimes are not sharp and the pictures used to describe them represent idealized descriptions of a very complex distribution of phases. Figure 9 shows the flow regimes which have been identified by Baker [6] in a horizontal pipe, and Fig. 10 is the flow regime map. The slug and plug regimes are





Fig. 10. Flow regime map for a horizontal pipe [6].

II. FLOW REGIME

B) Vertical Lines

GRIFFITH AND WALLIS CHART



Nomenclature:

- F_v = $Q_G / (Q_G + Q_L)$, flowing volumetric gas fraction
- N_{FR} = $\frac{(V_m)^2}{(g_c)(D_p)}$, Froude Number
- Q_G = gas flow, $ft^3/sec.$
- Q_L = liquid flow, $ft^3/sec.$
- V_m = $\frac{(Q_G + Q_L)}{(A_p)}$, two phase mixture velocity, $ft/sec.$
- A_p = cross sectional area of pipe, ft^2
- D_p = diameter of pipe, ft
- g_c = gravitational constant, $32.2 ft/sec^2$

Nitrogen

INPUT NEW VALUE ONLY FOR TEMP INPUT 1
QUIT INPUT Q
YOUR CHOICE P

NAME THE FIRST INPUT VARIABLE
(B BACKS UP ONE STEP, Q STOPS, ? FOR HELP)..... PRESS

NAME THE SECOND INPUT VARIABLE
(B BACKS UP ONE STEP, Q STOPS, ? FOR HELP)..... SAT

INPUT VALUE OF PRESSURE [PSI] 29.7

FLUID = NITROGEN

PRESSURE [PSI]	TEMP [K]	DENSITY [LB/FT3]	CP [J/G-K]	QUALITY [-]	ENTHALPY [J/G]	VISC [LBM/FT-S]
29.70	83.88	48.54	2.088	0.0000	-107.8	0.8097E-04
29.70	83.88	0.5525	1.179	1.000	81.76	0.3888E-05

DECIDE WHAT TO DO NEXT:
RETURN TO THE MAIN MENU INPUT M
SELECT NEW INPUT PARAMETERS INPUT P
INPUT NEW VALUE ONLY FOR PRESSURE INPUT 1
QUIT INPUT Q
YOUR CHOICE

NAME THE SECOND INPUT VARIABLE
(B BACKS UP ONE STEP, Q STOPS, ? FOR HELP)..... ENTHALPY

INPUT VALUE OF PRESSURE [PSI] 17

INPUT INITIAL VALUE OF ENTHALPY [J/G] -107.8

INPUT ITS INCREMENT (0 FOR ONE POINT)..... 0

FLUID = NITROGEN

PRESSURE [PSI]	TEMP [K]	DENSITY [LB/FT3]	CP [J/G-K]	QUALITY [-]	ENTHALPY [J/G]	VISC [LBM/FT-S]
17.00	78.62	50.12	2.066	0.0000	-118.8	0.9726E-04
17.00	78.62	5.313	0.0000	0.5578E-01	-107.8	0.0000
17.00	78.62	0.3293	1.132	1.000	78.17	0.3613E-05

DECIDE WHAT TO DO NEXT:
RETURN TO THE MAIN MENU INPUT M
SELECT NEW INPUT PARAMETERS INPUT P
INPUT NEW VALUES FOR BOTH PARAMETERS INPUT B
INPUT NEW VALUE ONLY FOR PRESSURE INPUT 1
INPUT NEW VALUES ONLY FOR ENTHALPY INPUT 2
QUIT INPUT Q
YOUR CHOICE

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-072 PAGE 1 OF 15
REV.	DEO #	DATE	BY:	CHECK	TITLE: 80K Pump Roughdown ΔP Analysis	
0		3/19/96	DJM	R. Shaw		
PROJECT: LIGO					BY: David Moore	DEPT.: 744
PROJECT NO: V59049						

PURPOSE: Determine if any significant pressure differential exists across the 5/16" gap separating the low e liner and the thermal radiation shield in the 80K pump during pumpdown which could structurally damage either of these components.

METHOD: Computer simulation of the roughdown of the 80K pump chamber volume. The computer program is a finite difference code which utilizes the Newton- Raphson method to solve the system equations.

ASSUMPTIONS: The gap which separates the low e liner and the radiation shield is modelled as a short pipe of equivalent diameter with entrance and exit losses equal to 1.5 velocity heads. The roughing process is assumed to be executed with the turbo backing pump, whose speed (90 cu. m./hr.) is approximately constant during the pressure range of interest.


INPUTS: Input file attached.

REFERENCES:

CALCULATIONS: Related calculations attached.

CONCLUSIONS: Delta P across the gap is insignificant. No significant structural loads.

Roughdown of Short 80K Pump Gate Valves Closed




```

FLUID BCD 3GENERAL
BCD 9 PRESS. VS TIME IN 80K PUMP CHAMBER
BCD 9 ROUGHDOWN CHAMBER WITH TURBO BACKING PUMP
END
BCD 3PRESSURE DATA
REM NODE #; ELEVATION, INIT PRESS; ETC.
-1, 0., 760.$
5, 0., 760.$
10, 0., 760.$
9999, 0., 1.0 $ DUMMY PRESSURE NODE

```

```

END
BCD 3TUBE DATA

```

```

C ABS TUBE #, INIT NODE, TERM NODE, A(REF #, ARRAY DATA)
TUB 10, 1, 5, A1, 0.0$
TUB 30, 1, 5, A1, 0.0$
PMI -20, 5, 10, A5, 0.0$

```

```

END
BCD 3CONSTANTS DATA

```

```

GRAV=32.2 $
GC1=89.6606 $CONVERSION TO TORR
GC2=1.0 $
USRFLO=0.1 $
C SPARE6 = 0. (1.) CAUSES "DEBUG" TO BE .FALSE. (.TRUE.).
SPARE6 = 1. $
C SPARE7 = 0. (1.) CAUSES "NOFERR" TO BE .FALSE. (.TRUE.).
SPARE7 = 1. $
C THE FOLLOWING LINE CAUSES ORDER REDUCTION TO BE SUPRESSED.
ISOLVE = 2
C THE FOLLOWING PARAMETERS CONTROL CONVERGENCE FOR THE FLUID
NETWORK SOLUTION AND OVERRIDE THE DEFAULT VALUES ...
KMAX=100 $
PRSABS=0.001 $
PRSREL=0.001 $
FLOABS=0.0001 $
FLOREL=0.0001 $
NDIM=10000$
NFLOOP= 10
PRLXCA= 0.001
EPS=0.01
PMPTOL=0.005
1=0.0 $ TOTAL MASS OUTFLOW, OUTER CHAM. VOLUME
5=0.0 $ TOTAL MASS OUTFLOW, INNER CHAM. VOLUME
10=760. $ PRESSURE IN OUTER CHAM. VOLUME (TORR)
50=760. $ PRESSURE IN INNER CHAM. VOLUME (TORR)
60=0. $ DELTA P
100= 0.0 $ ELAPSED TIME
200= .0662 $ PUMP FLOW
1000=2627. $ INITIAL AIR MASS, OUTER CHAM. VOLUME, GM.
2=16.0 $ TIME COUNTER
3=.075 $ INITIAL AIR DENSITY
6=.125 $ TIME STEP (SEC.)

```

```

END

```

```

BCD 3ARRAY DATA

```

```

REM L, D, K, E/D, FIVE EMPTY FIELDS
1, .125, .624, 1.50, .00018, 0.0, 0.0, 0.0, 0.0, 0.0, END$ANNULUS

```

```

PUMP CHARACTERISTICS

```

```

C--- MASS FLOW RATE VS. (DOWNSTREAM - UPSTREAM PRESS.)

```

```

5, .0, 15., 1.0, 15., END

```

```

C--- PUMP DOWN CURVE

```

```

7, 4., .0004, 13., .0011, 22., .0019, 27., .0024, 34., .0030

```

43.,.0037,53.,.0047,67.,.0058,85.,.0073
135.,.0117,170.,.0149,220.,.0190,355.,.0310
460.,.0398,590.,.0512,760.,.0662,END

END

BCD 3EXECUTION

```
C----- OBTAIN PUMP MASS FLOW FROM CHAMBER PRESSURE
          D1DEG1(XK10,A7,XK200)
F        OPEN(UNIT=7,FILE='PRESS.OUT',ACCESS='SEQUENTIAL',
F      +     STATUS='OLD',FORM='FORMATTED')
F        WRITE(7,50)
F 50     FORMAT(5X,'TIME(SEC)',5X,
F      +     'DP(TORR)',1X,'P1(TORR)',/)
F 100    CONTINUE
C----- SET PUMP MASS FLOW
M        W20=XK200
F        CONTINUE
          FLDSOL
F        CALL PMPFLO
M        IF(P1.GE.250.0)THEN
F        CONTINUE
M        IF(XK2.LE.0.)THEN
F          CALL DATPRT
F 105     CONTINUE
F        END IF
M        XK2=XK2-1.0
F        GO TO 100
F        ELSE
F        CONTINUE
F        END IF
          CLOSE(UNIT=7)
          END
          BCD 3VARIABLES F

          REM DYNAMIC VISCOSITY UNITS = LBM/FT-SEC
          TUBE(10,.0000123,K3,80.)
C        TUBE(20,.0000123,K3,80.)
          TUBE(30,.0000123,K3,80.)
          END
          BCD 3VARIABLES 1
          END
          BCD 3VARIABLES 2
          END
          BCD 3OUTPUT CALLS
M        IF(XK2.LE.0.)THEN
F          CALL PPRINT
F          CALL WPRINT
F        ELSE
F        CONTINUE
F        END IF
CM       IF(XK60.GE.2.0)THEN
CM       WRITE(7,800)XK100,XK60,P1
CM       ELSE
CM       CONTINUE
CM       END IF
F 000    FORMAT(5X,' ',F9.2,' ',F8.2,' ',F8.2)
          END
          BCD 3SINROUTINE PMPFLO
C----- COMPUTE MASS OUTFLOW DURING SELECTED TIME STEP
M        XK1=(W10+W30)*XK6*453.6
M        XK5=W20*XK6*453.6
```

```

C---- COMPUTE DELTA P ACROSS GAP
M      XK60=ABS(P5-P1)
C---- COMPUTE NEW PRESSURE IN CHAMBER OUTER VOLUME
C      -- OUTER VOLUME
M      XK10=.289*(XK1000-XK1)
M      P1=XK10
C
C---- COMPUTE ELAPSED TIME
M      XK100=XK100+XK6
C---- COMPUTE REMAINING AIR MASS
M      XK1000=XK1000-XK1
CM     XK5000=XK5000-XK5
C--- COMPUTE AIR DENSITY
M      XK3=XK1000/34926.
C----- UPDATE PUMP FLOW RATE
M      D1DEG1(XK10,A7,XK200)
M      W20=XK200
C
      END
      BCD 3SINROUTINE DATPRT
M      IF(XK2.LE.0.) THEN
M      XK2=16.0
F      END IF
M      WRITE(6,200)XK1,XK5
M      WRITE(6,300)XK100
M      WRITE(6,400)XK1000
M      WRITE(6,700)XK10
M      WRITE(6,600)XK200
M      WRITE(6,980)XK3
M      WRITE(7,800)XK100,XK60,P1
M      CONTINUE
C
F 200  FORMAT(/,5X,'MASS OUTFLOW FROM OUTER VOL.= ',F10.4,' GRAMS',
F      +      /,5X,'MASS OUTFLOW FROM INNER VOL.= ',F10.4,' GRAMS',/)
F 300  FORMAT(5X,'ELAPSED TIME = ',F10.3,' SEC.')
F 400  FORMAT(5X,'REMAINING MASS, OUTER CHAM.= ', F10.2,' GRAMS')
F 500  FORMAT(5X,'REMAINING MASS, INNER CHAM.= ', F10.2,' GRAMS')
F 600  FORMAT(/,5X,'PUMPFLOW= ',F10.4,' LBM/SEC')
F 700  FORMAT(/,5X,'OUTER CHAMBER PRESS= ',F10.4)
F 800  FORMAT(5X,' ',F9.2,' ',F10.4,' ',F8.2)
F 980  FORMAT(5X,'AIR DENSITY= ',F6.4,1X,'LBM/FT^3')
      END
      BCD 3END OF DATA

```


22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



Appendix
(Related Calculations)

Pumpdown of 80K
 Pump Chamber
 (Small Chamber)

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



Inner
 Volume

outer volume

PLAN VIEW

16 Jan., 1996

Calculation of Volumes

Calculate the outer chamber volume (ref: sketch) by calculating the gross chamber volume bounded by the chamber shell & heads, & subtracting out the volume inside the thermal radiation shield & the cross-hatched volume in the sketch:

$$\begin{aligned}\text{Shell: } V &= \frac{\pi d^2}{4} \times \text{length} \\ &= \frac{\pi (79\frac{1}{2})^2 (48)}{4} \\ &= 238,147 \text{ in}^3 (3.89 \text{ m}^3)\end{aligned}$$

Heads:

Volume of elliptically dished head is approximated by:

$$\begin{aligned}V &= 7.6 \times 10^{-5} d_i^3 && d_i: \text{in.} \\ \therefore V &= 7.6 \times 10^{-5} (79\frac{1}{2})^3 && V: \text{ft}^3 \\ &= 38.19 \text{ ft}^3\end{aligned}$$

For 2 heads, $76.37 \text{ ft}^3 (2.16 \text{ m}^3)$

\therefore Gross chamber volume (excluding the protruding beam ports) is:

$$\begin{array}{r} 2.16 \\ + 3.89 \\ \hline 6.05 \text{ m}^3 \end{array}$$



Volume inside the radiation shield:

$$\begin{aligned} V &= \frac{\pi}{4} d^2 \times \text{length} \\ &= \frac{\pi}{4} (72)^2 \times (50) \\ &= 203,472 \text{ in}^3 \quad (3.33 \text{ m}^3) \end{aligned}$$

Volume inside cross-hatched volume:

Approximate as cylinders $44\frac{1}{8}$ " dia. \times $10\frac{3}{4}$ " high

$$\begin{aligned} \therefore \text{Vol} &= 2 \times \frac{\pi}{4} d^2 \times \text{length} \\ &= 2 \left(\frac{\pi}{4} \right) \left(44\frac{1}{8} \right)^2 \left(10\frac{3}{4} \right) \\ &= 32877 \text{ in}^3 \quad (.54 \text{ m}^3) \end{aligned}$$

\therefore Outer chamber volume is

$$6.05 - (3.33 + .54) = 2.18 \text{ m}^3$$

#

The inner volume to be evacuated is the volume between closed gate valves. This includes the volume inside the radiation shield, the beam tube ports, and the spool piece on one end of the pump.

Beam tube ports:

$$\begin{aligned} V &= 2 \times \frac{\pi d_i^2}{4} \times \text{length} \\ &= 2 \left(\frac{\pi}{4} \right) \left(44 \frac{1}{8} \right)^2 \left(26 \frac{1}{4} \right) \\ &= 80282 \text{ in}^3 \quad (1.31 \text{ m}^3) \end{aligned}$$

Spool piece:

$$\begin{aligned} V &= \frac{\pi}{4} \left(44 \frac{5}{8} \right)^2 (36) \\ &= 56277 \text{ in}^3 \quad (.92 \text{ m}^3) \end{aligned}$$

∴ Total inner volume is:

$$3.33 + 1.31 + .92 = 5.56 \text{ m}^3$$

Mass of air in chamber :

Outer chamber volume initial air mass :

$$V = 2.18 \text{ m}^3$$

$$\begin{aligned} m &= \rho V = 2.18 \text{ m}^3 \left(2.65 \frac{\text{lbm}}{\text{m}^3} \right) \\ &= 5.79 \text{ lbm} \quad (2627 \text{ gm.}) \end{aligned}$$

Inner volume :

$$V = 5.56 \text{ m}^3$$

$$\begin{aligned} m &= 5.56 (2.65) \\ &= 14.73 \text{ lbm} \quad (6689 \text{ gm.}) \end{aligned}$$

//

Computations for computer simulation :

Density :

$$\rho = \frac{m}{V}$$

For the outer chamber volume

$$\rho = \frac{\text{XK1000}}{2180} \text{ gm./liter}$$

$$\text{or } \rho = \left(\frac{\text{XK1000}}{2180} \frac{\text{gm}}{\text{liter}} \right) \left(\frac{\text{liter}}{.03532 \text{ ft}^3} \right) \left(\frac{\text{lbm}}{453.6 \text{ gm}} \right)$$

$$\rho = \left(\frac{\text{XK1000}}{34926} \right) \frac{\text{lbm}}{\text{ft}^3}$$

Pressure computation

$$P = \frac{mRT}{VM}$$

$$M = 28.97 \frac{\text{gm}}{\text{mole}}$$

$$R = 62.36 \frac{\text{torr} \cdot \text{l}}{\text{mole} \cdot \text{K}}$$

$$P = \frac{m(62.36)(293)}{V(28.97)}$$

$$P = 630.703 (m/V)$$

∴ Outer volume :

$$P = 630.703 (m/2180)$$

$$P = .289 m \text{ torr}$$

Inner volume :

$$P = 630.703 (m/5560)$$

$$= .113 m \text{ torr}$$



Turbo Backing Pump Curve


Pump has an approximately constant speed ($90 \text{ m}^3/\text{hr}$)
for the pressures of interest.

<u>Pressure (Torr)</u>	<u>S (acfm)</u>	<u>ρ (lbm/ft³)</u>	<u>\dot{m} (lbm/sec)</u>
760	53.0	.0749	.0662
590		.0580	.0512
460		.0451	.0398
355		.0351	.0310
220		.0215	.0190
170		.0169	.0149
135		.0133	.0117
85		.0083	.0073
67		.0066	.0058
53		.0053	.0047
43		.0042	.0037
34		.0034	.0030
27		.0027	.0024
22		.0022	.0019
13		.0013	.0011
4		.0004	.0004



Pumpdown of 80K Pump Chamber

Fluid Flow Model:



50 SHEETS
22-141 100 SHEETS
22-142 200 SHEETS
22-144



30 K Cryopump
Annular Gap

For performance considerations, the annular gap area should be as large as the turbo inlet port (10" i.d.)

For one gap:

$$\frac{A}{2} = \frac{\pi}{4} (D_o^2 - D_i^2) \quad (\text{Area of one gap} = \frac{1}{2} \text{ total})$$

D_i defined by low e shield (44.62")

$$\frac{1}{2} \times \frac{\pi}{4} (10^2) = \frac{\pi}{4} (D_o^2 - 44.62^2)$$

$$D_o = 45.18" \text{ say } 45 \frac{1}{4}"$$

$$\begin{aligned} \therefore \text{Gap} &= (45 \frac{1}{4} - 44 \frac{5}{8}) / 2 \\ &= .3125 \text{ (} 5/16 \text{")} \end{aligned}$$

The equivalent pipe diameter of a 5/16" gap is

$$\frac{\pi}{4} (45 \frac{1}{4}^2 - 44 \frac{5}{8}^2) = \frac{\pi}{4} d_{equiv}^2$$

$$d_{equiv} = 7.49"$$

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-092 PAGE 1 OF 4
REV.	DEO #	DATE	BY:	CHECK	TITLE: Pressure Drop Calculations for 80K Pump Lines	
0	0122	4/12/96	D. Moore	R. Thom.		
					BY: D. Moore	DEPT.: 744
<u>PROJECT: LIGO</u>					<u>PROJECT NO: V59049</u>	
<u>PURPOSE:</u> To determine if regeneration and GN2 vent lines are adequately sized for the intended service.						
<u>METHOD:</u> Use of in-house computer program for pressure drop analysis.						
<u>ASSUMPTIONS:</u> 1) The length of each of the lines are equivalent to 60 ft. of straight pipe. 2) Regen. flow rate is 100 gm./sec.						
<u>INPUTS:</u> Regen. heater delta p = .35 psid max. (vendor data) Vaporizer delta p = 2 psid (budget imposed on vendor) Estimated Cv for 1-1/2" globe valve in regen line = 31.66						
<u>REFERENCES:</u>						
<u>CALCULATIONS:</u> Calculations performed for : Case 1) 80K pump normal operation (long pump, frosted) Case 2) Long 80K pump cooldown from 150C (423K) Case 3) Regen of Long 80K pump.						
<u>CONCLUSIONS:</u> Case 1): Delta p = .0017 psid for 1-1/2 in. vent line. Case 2): Delta p = .1392 psid for 1-1/2 in. vent line. Case 3): Delta p = 9.413 psid from LN2 dewar to exit of vent line. (by inspection, the 80K short pump system is adequate for 50 gm/sec.) <u>Conclusion:</u> The lines are adequately sized for their intended service.						

PROCESS SYSTEMS INTERNATIONAL, INC 20 Walkup Drive, Westborough, MA 01581

CUSTOMER: LIGO

JOB NO: V59049

PAGE: 1

PRESSURE DROP ROUTE OR LINE ID: GN2 VENT, NORMAL OP.

PRESSURE: 101270.8 Pa 14.684 PSIA
 TEMPERATURE: 77.778 K 140.000 R
 DENSITY: 4.581 KG/M³ 0.29 LBS/FT³
 QUALITY: 1.000

ITEMNAME	FLOWRATE LB/S	I.D. INCHES	K / DO	CV	LENGTH FT	PRESSURE PSIA	Z1 FEET	Z2 FEET	DP-F PSI	DP-Z PSI	DP-T PSI	DP-SUM PSI
1.5" PIPE	0.0096	1.6820			6.00	14.684	0.00	0.00	0.00017	0.0000	0.0002	0.0002
1.5" PIPE	0.0096	1.6820			6.00	14.684	0.00	0.00	0.00017	0.0000	0.0002	0.0003
1.5" PIPE	0.0096	1.6820			6.00	14.684	0.00	0.00	0.00017	0.0000	0.0002	0.0005
1.5" PIPE	0.0096	1.6820			6.00	14.684	0.00	0.00	0.00017	0.0000	0.0002	0.0007
1.5" PIPE	0.0096	1.6820			6.00	14.683	0.00	0.00	0.00017	0.0000	0.0002	0.0008
1.5" PIPE	0.0096	1.6820			6.00	14.683	0.00	0.00	0.00017	0.0000	0.0002	0.0010
1.5" PIPE	0.0096	1.6820			6.00	14.683	0.00	0.00	0.00017	0.0000	0.0002	0.0012
1.5" PIPE	0.0096	1.6820			6.00	14.683	0.00	0.00	0.00017	0.0000	0.0002	0.0014
1.5" PIPE	0.0096	1.6820			6.00	14.683	0.00	0.00	0.00017	0.0000	0.0002	0.0015
1.5" PIPE	0.0096	1.6820			6.00	14.683	0.00	0.00	0.00017	0.0000	0.0002	0.0017
TOTAL										0.0017	0.0000	0.0017

BLOWER SUCTION DENSITY: 4.581 KG/M³ 0.286 LB/FT³

V049-11092
 P 2 9th A

PROCESS SYSTEMS INTERNATIONAL, INC 20 Walkup Drive, Westborough, MA 01581

CUSTOMER: LIGO

JOB NO: V59049

PAGE: 1

PRESSURE DROP ROUTE OR LINE ID: GN2 VENT, COOLDOWN FROM 423K

PRESSURE: 101270.8 Pa 14.684 PSIA
 TEMPERATURE: 77.778 K 140.000 R
 DENSITY: 4.581 KG/M³ 0.29 LBS/FT³
 QUALITY: 1.000

ITEMNAME	FLOWRATE LB/S	I.D. INCHES	K / DO	CV	LENGTH FT	PRESSURE PSIA	Z1 FEET	Z2 FEET	DP-F PSI	DP-Z PSI	DP-T PSI	DP-SUM PSI
1.5" PIPE	0.0983	1.6820			6.00	14.670	0.00	0.00	0.01386	0.0000	0.0139	0.0139
1.5" PIPE	0.0983	1.6820			6.00	14.657	0.00	0.00	0.01387	0.0000	0.0139	0.0277
1.5" PIPE	0.0983	1.6820			6.00	14.643	0.00	0.00	0.01389	0.0000	0.0139	0.0416
1.5" PIPE	0.0983	1.6820			6.00	14.629	0.00	0.00	0.01390	0.0000	0.0139	0.0555
1.5" PIPE	0.0983	1.6820			6.00	14.615	0.00	0.00	0.01391	0.0000	0.0139	0.0694
1.5" PIPE	0.0983	1.6820			6.00	14.601	0.00	0.00	0.01393	0.0000	0.0139	0.0834
1.5" PIPE	0.0983	1.6820			6.00	14.587	0.00	0.00	0.01394	0.0000	0.0139	0.0973
1.5" PIPE	0.0983	1.6820			6.00	14.573	0.00	0.00	0.01396	0.0000	0.0140	0.1113
1.5" PIPE	0.0983	1.6820			6.00	14.559	0.00	0.00	0.01397	0.0000	0.0140	0.1252
1.5" PIPE	0.0983	1.6820			6.00	14.545	0.00	0.00	0.01398	0.0000	0.0140	0.1392
TOTAL									0.1392	0.0000		0.1392

BLOWER SUCTION DENSITY: 4.536 KG/M³ 0.283 LB/FT³

V049-1
 07/09/92

PROCESS SYSTEMS INTERNATIONAL, INC 20 Walkup Drive, Westborough, MA 01581
 CUSTOMER: LIGO

PRESSURE DROP ROUTE OR LINE ID: REGEN PUMP TO 423K(300F), VAPORIZER TO VENT 100 GM/SEC.

PRESSURE: 156520.5 Pa 22.695 PSIA
 TEMPERATURE: 423.000 K 761.400 R
 DENSITY: 1.246 KG/M³ 0.08 LBS/FT³
 QUALITY: 1.000

JOB NO: V59049 PAGE: 1

ITEMNAME	FLOWRATE LB/S	I. D. INCHES	K / DO	CV	LENGTH FT	PRESSURE PSIA	Z1 FEET	Z2 FEET	DP-F PSI	DP-Z PSI	DP-T PSI	DP-SUM PSI
VAPORIZER	0.2203	1.6820		31.660		20.695	0.00	0.00	2.00000	0.0000	2.0000	2.0000
1.5" GLOBE	0.2203	1.6820			10.00	18.5	0.00	0.00	2.22355	0.0000	2.2236	4.2236
1.5" PIPE	0.2203	1.6820				17.926	0.00	0.00	0.54589	0.0000	0.5459	4.7694
HEATER	0.2203	3.2600			6.00	17.564	0.00	0.00	0.35000	0.0000	0.3500	5.1194
3.0" PIPE	0.2203	3.2600			6.00	17.551	0.00	0.00	0.01247	0.0000	0.0125	5.1319
3.0" PIPE	0.2203	3.2600			6.00	17.539	0.00	0.00	0.01247	0.0000	0.0125	5.1444
3.0" PIPE	0.2203	3.2600			6.00	17.526	0.00	0.00	0.01248	0.0000	0.0125	5.1569
3.0" PIPE	0.2203	3.2600			6.00	17.514	0.00	0.00	0.01249	0.0000	0.0125	5.1694
3.0" PIPE	0.2203	3.2600			6.00	17.501	0.00	0.00	0.01250	0.0000	0.0125	5.1819
3.0" PIPE	0.2203	3.2600			6.00	17.489	0.00	0.00	0.01252	0.0000	0.0125	5.1944
3.0" PIPE	0.2203	3.2600			6.00	17.476	0.00	0.00	0.01253	0.0000	0.0125	5.2069
3.0" PIPE	0.2203	3.2600			6.00	17.464	0.00	0.00	0.01254	0.0000	0.0125	5.2194
3.0" PIPE	0.2203	3.2600			6.00	17.451	0.00	0.00	0.01255	0.0000	0.0125	5.2320
80K PUMP	0.2203	0.0000			6.00	17.201	0.00	0.00	0.25000	0.0000	0.2500	5.2445
1.5" PIPE	0.2203	1.6820			6.00	16.849	0.00	0.00	0.35172	0.0000	0.3517	5.4945
1.5" PIPE	0.2203	1.6820			6.00	16.490	0.00	0.00	0.35906	0.0000	0.3591	6.2053
1.5" PIPE	0.2203	1.6820			6.00	16.123	0.00	0.00	0.36688	0.0000	0.3669	6.5722
1.5" PIPE	0.2203	1.6820			6.00	15.748	0.00	0.00	0.37522	0.0000	0.3752	6.9474
1.5" PIPE	0.2203	1.6820			6.00	15.364	0.00	0.00	0.38416	0.0000	0.3842	7.3315
1.5" PIPE	0.2203	1.6820			6.00	14.970	0.00	0.00	0.39376	0.0000	0.3938	7.7253
1.5" PIPE	0.2203	1.6820			6.00	14.566	0.00	0.00	0.40411	0.0000	0.4041	8.1294
1.5" PIPE	0.2203	1.6820			6.00	14.151	0.00	0.00	0.41532	0.0000	0.4153	8.5447
1.5" PIPE	0.2203	1.6820			6.00	13.723	0.00	0.00	0.42750	0.0000	0.4275	8.9722
1.5" PIPE	0.2203	1.6820			6.00	13.282	0.00	0.00	0.44082	0.0000	0.4408	9.4130
TOTAL									9.4130	0.0000	9.4130	9.4130

TOTAL

BLOWER SUCTION DENSITY: 0.730 KG/M³ 0.046 LB/FT³

V049-1-092
Pg 4 of 4

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA				ENGINEERING CALCULATIONS	NO: V049-1-094 PAGE 1 OF 15
REV.	DEO #	DATE	BY:	CHECK	TITLE: <u>Relieving requirements for 80K pump vacuum shell relief device.</u>
0	0124	4/19/96	D Moore	D.M.W.	
1	0307	10/15/96	D Moore	D.M.W.	
				BY: D.Moore	DEPT.: 744
<u>PROJECT: LIGO</u>				<u>PROJECT NO: V59049</u>	
<p><u>PURPOSE:</u> To determine the relieving requirements for the vacuum shell of the 80K pump so that in the event of a failure of the 80K pump reservoir, the vacuum shell and the large gate valves in the beam tube are protected from overpressure.</p>					
<p><u>METHOD:</u> Standard thermodynamic and heat transfer analyses, and the use of standard API formula for sizing relief valve orifice.</p>					
<p><u>ASSUMPTIONS:</u> See calculations</p>					
<p><u>INPUTS:</u> Maximum delta p allowed, 1.75 atm., is based on highest pressure differential the large gate valves were designed for.</p>					
<p><u>REFERENCES</u> API 520</p>					
<p><u>CALCULATIONS:</u> See attached.</p>					
<p><u>CONCLUSIONS:</u> Relieving device should be sized to handle a flow rate of 6524 lbm/hr for the set pressure. This requires an orifice size of 3.36 sq. in.</p>					

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-094
		Rev. No. 1
		Page 1a of 15
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Relieving Requirements for 80K Pump Vacuum Shell Relief Device		

REVISION HISTORY

Rev. 0 Original Issue - April 19, 1996

Rev. 1 Issue Date - Oct. 15, 1996

- Revised sizing of burst disc to take pressure drop of vent line into account.
Relieving area increased to 3.36 sq. in.

Cases to consider for sizing relief device:

1. Leak in the LN₂ reservoir cools the entire pump vacuum shell to 80K. Control valve is sized for approx. 9 lbm/hr., so it plays no significant role in this case.
2. Catastrophic rupture of LN₂ reservoir dumps entire liquid inventory at the bottom of the vacuum shell. Vent presumed blocked with ice.
3. LN₂ reservoir ruptures during cool-down. Manual cooldown valve is 100% open. GN₂ vent is open, since it will not have had sufficient time to ice up, and ∴ provides another relieving path. This case less severe than first two cases.
4. LN₂ reservoir ruptures during regen. cycle when pump is warming up. No liquid in reservoir. Max flow for regen is 10600 SCFH (~800 lbm/hr). This case is less severe than the first 2 cases



Case 1: A leak in the LN₂ reservoir cools the entire vacuum chamber shell to 80K (highly unlikely). Heat is then transferred from the environment to the shell. The relieving device must then pass the following flow rate (see analysis, Attachment 1):


$$\dot{m} = \frac{Q\beta}{c_p}$$

Q = heat transferred from environment to cold vacuum shell.

c_p = specific heat of N₂

β = volume coefficient of expansion

Approximate Surface Area:
 Long Pump



$$a = 40''$$

$$h = 12\frac{1}{2}''$$

$$\text{Cylinder area} = \pi(80)(146) = 36,694 \text{ in}^2$$

$$\text{Ports: area} = 2(\pi)(44)(15) = 4197 \text{ in}^2$$

Dished heads:

$$A = 2 \times \pi(a^2 + h^2)$$


$$= 2\pi(40^2 + (12\frac{1}{2})^2)$$

$$= 11035 \text{ in}^2$$

Total:

36694
4197
<u>11035</u>
51876 in ² (3.346 x 10 ⁵ cm ²)

Heat transferred to cold shell (per unit area):



Energy balance:

$$\frac{kA}{t}(T-144) = hA(527-T) + \sigma A \epsilon (527^4 - T^4)$$

$$A = 1.0 \text{ ft}^2$$

$$\epsilon = 1.0$$

$$h = 0.27 \left(\frac{\Delta T}{d} \right)^{1/4}$$

d = dia of cylinder
(ft.)

$$= 6.667 \text{ ft}$$

$$k = 4.8 \frac{\text{Btu}}{\text{hr-ft}^2 \text{ } ^\circ\text{F}}$$

(near 80K)

$$\frac{k}{t}(T-144) = 0.27 \left(\frac{527-T}{d} \right)^{1/4} (527-T) + \sigma (527^4 - T^4)$$

$$\frac{4.8}{0.208}(T-144) = .17(527-T)^{5/4}(527-T) + .1714 \times 10^{-8}(527^4 - T^4)$$

$$230.77(T-144) = .17(527-T)^{5/4} + .1714 \times 10^{-8}(527^4 - T^4)$$

Solution: $T = 146^\circ\text{R}$

$$Q = .17(527-146)^{5/4} + .1714 \times 10^{-8}(527^4 - 146^4)$$
$$= 418 \frac{\text{Btu}}{\text{hr-ft}^2}$$

$$\therefore Q_{total} = 418 \frac{\text{Btu}}{\text{hr-ft}^2} \times \left(\frac{51876}{144} \right) \text{ft}^2$$

$$= 150,585 \frac{\text{Btu}}{\text{hr}}$$

at 2 psig (16.7 psia) @ 144 °R

$$\beta = \frac{1}{V} \left(\frac{dV}{dT} \right)_P$$

$$= .00789 \text{ } 1/^\circ\text{R}$$

$$\# C_p = .27 \text{ Btu/lbm-}^\circ\text{R}$$

$$\therefore \dot{m} = \frac{(150585)(.00789)}{.27}$$


$$= 4402 \frac{\text{lbm}}{\text{hr}} \left(1.22 \frac{\text{lbm}}{\text{sec}} \right)$$

—//

Large gate valves at ends of pump are designed for $1\frac{3}{4}$ atm. differential pressure.

$$1.75 (14.7) = 25.73 \text{ psia (11 psig)}$$


Case 2: Catastrophic rupture of LN₂ reservoir;
 LN₂ inventory collects at bottom of
 vacuum chamber; energy stored in 70°F
 vacuum chamber vaporizes liquid.



Reservoir (assume full)

$$A = \pi (29.375^2 - 27.125^2)$$

$$= 399.4 \text{ in}^2$$



Vacuum chamber
 with reservoir liquid
 inventory at bottom.

$$A = 399.4 \text{ in}^2$$

$$A = \frac{1}{2} r^2 (\theta - \sin \theta)$$

$$399.4 = \frac{1}{2} (39.75)^2 (\theta - \sin \theta)$$

$$\text{Solution: } \theta = 1.503 \text{ rad.}$$

Arc length s:

$$s = r \theta$$

$$= 39.75 (1.503)$$

$$= 59.74 \text{ ''}$$

∴ Total area at the liquid/vacuum shell interface is approximately

$$(14 \text{ ft}) \left(\frac{12 \text{ in.}}{\text{ft}} \right) (59.74 \text{ in.}) = 10,036 \text{ in}^2 \\ (69.69 \text{ ft}^2)$$

Due to the large temperature excess ($70^\circ\text{F} - (-320^\circ\text{F})$), the liquid will form a vapor blanket between it & the vacuum chamber, resulting in film boiling.


Referring to published boiling data for nitrogen, the heat flux at 390°F excess temperature is 8000 Btu/hr-ft^2

$$\text{or } Q_{\text{total}} = 8000 (69.69) \\ = 557,520 \text{ Btu/hr}$$

∴ vapor generation is :

$$\dot{m} = \frac{557,520 \text{ Btu/hr}}{85.46 \text{ Btu/lbm}} \\ = 6524 \text{ lbm/hr.}$$

Since mass flow rate is so large, pressure drop across vent line must be considered in sizing the required orifice area, and density changes must be considered.



$$\text{Vent line length} = 63.2 \text{ ft plus } 4\text{-}90^\circ \text{ miterers} \\ (\text{Lequiv} = 63 \text{ ft})$$

$$\text{Total Lequiv} = \frac{63.2}{63} \\ 126.2 \text{ ft.}$$


Since the pressure in the 80K pump is 25.7 psia, the flow in the vent will not choke & the pressure at the vent exit will be 14.7 psia.

Worst case assumption is that the vapor is that N_2 is at room temperature.

$$\therefore P_3 = 25.7 \text{ psia}$$

$$T_3 = 70^\circ \text{ F } (530^\circ \text{ R})$$

$$= T_0 = \text{constant (treat as adiabatic flow)}$$



$$\frac{w}{a} = \sqrt{\frac{k}{R}} \frac{P}{\sqrt{T_0}} M \sqrt{1 + \frac{k-1}{2} M^2}$$

$$R = 55.13 \frac{\text{ft-lbf}}{\text{lbm-}^\circ\text{R}} \quad P = 14.7(144) = 2117 \frac{\text{lbf}}{\text{ft}^2}$$

$$\frac{w}{A} = \frac{6529 \text{ lbm/hr}}{0.099 \text{ ft}^2} \times \frac{1}{3600} = 18.31 \frac{\text{lbm}}{\text{ft}^2\text{-sec}}$$

Solve for M_2 :

$$18.31 = \sqrt{\frac{1.4(32.16)}{55.13}} \frac{2117}{\sqrt{460+70}} M \sqrt{1 + .2M^2}$$

$$0.22 = M \sqrt{1 + .2M^2}$$

M	$M \sqrt{1 + .2M^2}$
.215	.216
.217	.218
root → .22	.221

$$\therefore M_2 = .22 \quad \& \quad (P/P^*)_{M_2} = 5.015$$



From tables of compressible flow functions (pg 13, attached)

$$(4fL_{\max}/D)_2 = 12.11$$

$$\text{Reynolds no} = \frac{\rho V D}{\mu} = \frac{w D}{\mu A}$$

$$= \frac{18.31(.355)}{1.17 \times 10^{-5}}$$

(Eval. at 70°F)

$$= 555,600$$

$$4\bar{f} = .0172$$

$$\frac{4\bar{f}L}{D} = .0172 \left(\frac{126.2}{.355} \right)$$

$$= 6.11$$

$$\frac{4\bar{f}L}{D} = \left(4\bar{f} \frac{L_{\max}}{D} \right)_{M_1} - \left(4\bar{f} \frac{L_{\max}}{D} \right)_{M_2}$$

$$\therefore \left(4\bar{f} \frac{L_{\max}}{D} \right)_{M_1} = 6.11 + 12.11$$

$$= 18.22$$

From tables,

$$M_1 = .186$$

$$\downarrow (P/P^*)_{M_1} = 5.96$$

$$\frac{P_2}{P_1} = \frac{(P/P^*)_{M_2}}{(P/P^*)_{M_1}}$$

$$\therefore P_1 = 14.7 \left(\frac{5.96}{5.015} \right)$$

$$P_2 = 17.47 \text{ psia}$$

\therefore Size burst disc for 25.7 - 17.47
= 8.23 psid

50 SHEETS
100 SHEETS
200 SHEETS

22-141
22-142
22-144



TABLE B.4
 FRICTIONAL, ADIABATIC, CONSTANT-AREA FLOW (FANNO LINE)
 Perfect Gas, $k = 1.4$

M	T/T*	p/p*	p ₀ /p ₀ *	V/V* and ρ*/ρ	F/F*	4fL _{max} /D
0.00	1.2000	∞	∞	0.00000	∞	∞
.05	1.1994	21.903	11.5914	.05476	9.1584	280.02
.10	1.1976	10.9435	5.8218	.10943	4.6236	66.922
.15	1.1946	7.2866	3.9103	.16395	3.1317	27.932
.20	1.1905	5.4555	2.9635	.21822	2.4004	14.533
.25	1.1852	4.3546	2.4027	.27217	1.9732	8.4834
.30	1.1788	3.6190	2.0351	.32572	1.6979	5.2992
.35	1.1713	3.0922	1.7780	.37880	1.5094	3.4525
.40	1.1628	2.6958	1.5901	.43133	1.3749	2.3085
.45	1.1533	2.3865	1.4486	.48326	1.2763	1.5664
.50	1.1429	2.1381	1.3399	.53453	1.2027	1.06908
.55	1.1315	1.9341	1.2549	.58506	1.1472	.72805
.60	1.1194	1.7634	1.1882	.63481	1.10504	.49081
.65	1.10650	1.6183	1.1356	.68374	1.07314	.32460
.70	1.09290	1.4934	1.09436	.73179	1.04915	.20814
.75	1.07856	1.3848	1.06242	.77893	1.03137	.12728
.80	1.06383	1.2892	1.03823	.82514	1.01853	.07229
.85	1.04849	1.2047	1.02067	.87037	1.00966	.03632
.90	1.03270	1.12913	1.00887	.91459	1.00399	.014513
.95	1.01652	1.06129	1.00215	.95782	1.00033	.003280
1.00	1.00000	1.00000	1.00000	1.00000	1.00000	0
1.05	.98320	.94435	1.00203	1.04115	1.00082	.002712
1.10	.96618	.89359	1.00793	1.08124	1.00305	.009933
1.15	.94899	.84710	1.01746	1.1203	1.00646	.02053
1.20	.93168	.80436	1.03044	1.1583	1.01082	.03364
1.25	.91429	.76495	1.04676	1.1952	1.01594	.04858
1.30	.89686	.72848	1.06630	1.2311	1.02169	.06483
1.35	.87944	.69466	1.08904	1.2660	1.02794	.08199
1.40	.86207	.66320	1.1149	1.2999	1.03458	.09974
1.45	.84477	.63387	1.1440	1.3327	1.04153	.11782
1.50	.82759	.60648	1.1762	1.3646	1.04870	.13605
1.55	.81054	.58084	1.2116	1.3955	1.05604	.15427
1.60	.79365	.55679	1.2502	1.4254	1.06348	.17236
1.65	.77695	.53421	1.2922	1.4544	1.07098	.19022
1.70	.76046	.51297	1.3376	1.4825	1.07851	.20780
1.75	.74419	.49295	1.3865	1.5097	1.08603	.22504
1.80	.72816	.47407	1.4390	1.5360	1.09352	.24189
1.85	.71238	.45623	1.4952	1.5614	1.1009	.25832
1.90	.69686	.43936	1.5552	1.5861	1.1083	.27433
1.95	.68162	.42339	1.6193	1.6099	1.1155	.28989
2.00	.66667	.40825	1.6875	1.6330	1.1227	.30499
2.05	.65200	.39389	1.7600	1.6553	1.1297	.31965
2.10	.63762	.38024	1.8369	1.6769	1.1366	.33385
2.15	.62354	.36728	1.9185	1.6977	1.1434	.34760
2.20	.60976	.35494	2.0050	1.7179	1.1500	.36091

TABLE B.4. F

M	T/T*
2.25	.59627
2.30	.58309
2.35	.57021
2.40	.55762
2.45	.54533
2.50	.53333
2.55	.52163
2.60	.51020
2.65	.49906
2.70	.48820
2.75	.47761
2.80	.46729
2.85	.45723
2.90	.44742
2.95	.43788
3.00	.42857
3.50	.34785
4.00	.28571
4.50	.23761
5.00	.20000
6.00	.14633
7.00	.11111
8.00	.08696
9.00	.06971
10.00	.05714
∞	0

Rev. 1

V049-1-094
 Pg 13 of 15

Use sizing formula for subcritical flow from
API 520 :

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



4.3.3 SIZING FOR SUBCRITICAL FLOW: GAS OR VAPOR OTHER THAN STEAM

4.3.3.1 General

When the ratio of back pressure to inlet pressure exceeds the critical pressure ratio P_c/P_1 , the flow through the pressure relief valve is subcritical (see 4.3.1). Equations 5-7 may be used to calculate the required effective discharge area for a conventional relief valve that has its spring setting adjusted to compensate

for superimposed back pressure and for sizing a pilot-operated relief valve.

Note: Balanced-bellows relief valves that operate in the subcritical region should be sized using Equations 2-4. The back pressure correction factor for this application should be obtained from the valve manufacturer.

$$A = \frac{W}{735F_2K_d} \sqrt{\frac{ZT}{MP_1(P_1 - P_2)}} \quad (5)$$

$$A = \frac{V}{4645.2F_2K_d} \sqrt{\frac{ZTM}{P_1(P_1 - P_2)}} \quad (6)$$

$$A = \frac{V}{863.63F_2K_d} \sqrt{\frac{ZTG}{P_1(P_1 - P_2)}} \quad (7)$$

Where:

A = required effective discharge area of the valve, in square inches (see 1.2.2).

W = required flow through the valve, in pounds per hour.

F_2 = coefficient of subcritical flow (see Figure 29 for values)

$$= \sqrt{\left(\frac{k}{k-1}\right) (r)^{2k} \left[\frac{1-r^{(k-1)/k}}{1-r}\right]}$$

k = ratio of the specific heats.

r = ratio of back pressure to upstream relieving pressure, P_2/P_1 .

K_d = effective coefficient of discharge
= 0.975 for use in Equations 5-7.

Z = compressibility factor for the deviation of the actual gas from a perfect gas, a factor evaluated at relieving inlet conditions.

T = relieving temperature of the inlet gas or vapor, in degrees Rankine (degrees Fahrenheit + 460).

M = molecular weight of the gas or vapor. Various handbooks carry tables of molecular weights of materials, but the composition of the flowing gas or vapor is seldom the same as that listed in the tables. This value should be obtained from

the process data. Table 8 lists values for some common fluids.

P_1 = upstream relieving pressure, in pounds per square inch absolute. This is the set pressure plus the allowable overpressure (see 4.2) plus atmospheric pressure, in pounds per square inch absolute.

P_2 = back pressure, in pounds per square inch absolute.

V = required flow through the valve, in standard cubic feet per minute at 14.7 pounds per square inch absolute and 60°F.

G = specific gravity of gas referred to air
= 1.00 for air at 14.7 pounds per square inch absolute and 60°F.

4.3.3.2 Example

In this example, the following relief requirements are given:

$$A = \frac{6524}{735(.811)(.975)} \\ \times \sqrt{\frac{1.0(530)}{28.02(25.7)(25.7-17.47)}}$$

$$A = 3.357 \text{ in}^2$$

where:

$$r = \frac{17.47}{25.7} = 0.679$$

$$F_2 = \sqrt{\left(\frac{1.4}{A}\right)(.679)^{1.429}}$$

$$\times \sqrt{\frac{1 - (.679)^{2.86}}{1 - .679}}$$

$$= .811$$

∴ Required diameter of relieving area is:

$$d = \sqrt{\frac{4A}{\pi}} \\ = \sqrt{\frac{4(3.357)}{\pi}}$$

$$d = 2.07 \text{ in.}$$

Attachment 1

mass flow: $\dot{m} = \frac{dm}{dt}$

st. 1 ad: $d(mu) = dQ + h\dot{m} = \frac{dQ}{dt} + h \frac{dm}{dt}$

$$u \frac{dm}{dt} + m \frac{du}{dt} = \frac{dQ}{dt} + h \frac{dm}{dt}$$

$$m \frac{du}{dt} = \frac{dQ}{dt} + (h-u) \frac{dm}{dt}$$

$$h = u + pv$$

$$m \frac{du}{dt} = \frac{dQ}{dt} + pv \frac{dm}{dt}$$

$$\frac{dQ}{dt} = m \frac{du}{dt} - pv \frac{dm}{dt}$$

Const. Volume (Control volume): $m = \frac{\sqrt{V}}{v}$

Const pressure process: $h = u + pv$

$$dh = du + p dv$$

$$dm = -\frac{\sqrt{V} dv}{v^2}$$

$$\frac{dQ}{dt} = m \frac{du}{dt} + \frac{\sqrt{V} p}{v} \frac{dv}{dt} = \frac{\sqrt{V}}{v} \left(\frac{du}{dt} + p \frac{dv}{dt} \right) = \frac{\sqrt{V}}{v} \frac{dh}{dt}$$

$$\dot{m} = \frac{dm}{dt} = -\frac{\sqrt{V}}{v^2} \frac{dv}{dt}$$

$$\frac{Q}{\dot{m}} = + \frac{v dh}{dv}$$

at const pressure $\left(\frac{1}{v} \frac{dv}{dT} \right) = \alpha$ & $\frac{dh}{dT} = c_p$


$$dh = c_p dT \quad \& \quad dv = \frac{\alpha}{T} v dT$$

$$\frac{dh}{dv} = \frac{c_p T}{\alpha v}$$

$$\frac{Q}{\dot{m}} = \frac{c_p T}{\alpha}$$

\Rightarrow

$$\dot{m} = \frac{\alpha Q}{c_p T}$$



22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



Attachment 1 (cont.)

But by definition,

$$\beta = \frac{1}{V} \left(\frac{\partial V}{\partial T} \right)_P$$

$$\therefore \frac{3 \cdot \beta \cdot T}{\beta} = \frac{c_p T}{T \left(\frac{\partial V}{\partial T} \right)}$$

$$= \frac{c_p}{\beta}$$

$$\text{or } \dot{m} = \frac{\dot{Q} \beta}{c_p}$$

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



PROCESS SYSTEMS INTERNATIONAL, INC 20 Walkup Drive, Westborough, MA 01581

CUSTOMER: LIGO JOB NO: V59049 PAGE: 1

PRESSURE DROP ROUTE OR LINE ID:

PRESSURE: 100000.0 Pa 1.000 BAR
 TEMPERATURE: 293.000 K 293.000 K
 DENSITY: 1.150 KG/M³ 0.115E+01 KG/M³
 QUALITY: 1.000

ITEMNAME	FLOWRATE KG/S	I.D. METER	K / DO	CV	LENGTH M	PRESSURE Pa	Z1 METER	Z2 METER	DP-F Pa	DP-Z Pa	DP-T Pa	DP-SUM Pa	DENSITY KG/M ³	VELOCITY M/S	RE NO
EQ PIPE LENGTH	0.800E-03	0.0900			1.00	99999.99	0.00	0.00	0.01	0.00	0.01	0.01	0.115E+01	0.109	0.642E+03
EXPANSION LOSS	0.800E-03	0.0900	1.5000			99999.982	0.00	0.00	0.01	0.00	0.01	0.02	0.115E+01		

TOTAL 0.0179 0.0000 0.0179

0.018 Pa = 0.0001 Torr ✓

$$\frac{1}{2} \rho V^2 = \frac{1}{2} 1.1 \cdot 0.1^2 = 0.0055 \text{ Pa.}$$

No collapse problem due to pump down.

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1-096 PAGE 1 OF 12
REV.	DEO #	DATE	BY:	CHECK	TITLE: Regen. System Process Calculations	
0	130	4/19/96	D Moore	J.M.W		
					BY: D. Moore	DEPT.: 744
<u>PROJECT: LIGO</u>					<u>PROJECT NO: V59049</u>	
<u>PURPOSE:</u> Determine process requirements for the 80K pump regen. heaters, and to estimate the warmup time (time to reach 150 deg. C) for the pump under wintertime conditions in Washington.						
<u>METHOD:</u> Standard heat transfer manual calculations and on spreadsheet format.						
<u>ASSUMPTIONS:</u> Used weather conditions for Kennewick, Washington: 15 deg. F dry bulb (Above this temperature 97.5% of the time.)						
<u>INPUTS:</u> Max. regen flowrate = 100 gm/sec for long pump; 50 gm/sec for short pump. N2 temperature from the vaporizer = -5 deg. F (20 deg. F approach temp. specified by mfg.)						
<u>REFERENCES:</u>						
<u>CALCULATIONS:</u> See attached.						
<u>CONCLUSIONS:</u> Long pump heater size: 25 kw adequate. Short pump heater size: 12 kw adequate. Estimated warmup times, including liquid vaporization: long pump = 16.75 hrs., short pump = 8.0 hrs.						

80K Pump Regeneration Process Calculations

Sizing of Regen Heaters:


Heaters must be sized to deliver hot N_2 gas to the 80K pumps. The 80K pumps are to be heated to $302^\circ F$ ($150^\circ C$). Assuming a $20^\circ F$ approach temperature, the gas temperature entering the cryopump should be about $325^\circ F$.

Wintertime Operation:

Using available design data, size the heater for $15^\circ F$ dry bulb wintertime conditions (see Attachment 1). Assume a 10 m.p.h. wind blowing across the line supplying the regen. gas to the cryopump. \therefore Calculate the temperature exiting the heater in order to overcome heat losses from the supply line.

Heat Loss thru 60 ft. of regen pipe:

Long pump:




\dot{m}_{in}
 $= 100 \text{ gm/sec}$
 $(.22 \text{ lbm/sec})$

$1\frac{1}{2}''$ insul.
 on $3'' \phi$ pipe
 $T_{amb} = 15^\circ\text{F}$

$T_{out} = 325^\circ\text{F}$

$T_{in} = ?$



$1\frac{1}{2}''$ thick, insul.
 $k = .04$
 $\frac{\text{Btu}}{\text{hr-ft-F}}$

$T_o = ?$ $T_{amb} = 15^\circ\text{F}$

$\dot{q}_{in} = \dot{q}_{out}$

$kS(T_i - T_o) = hA(T_o - T_{amb})$

Assume 10 mph wind

$S = \frac{2\pi L}{\ln(r_o/r_i)}$
 $= \frac{2\pi(1.0)}{\ln(6.5/3.5)} = 10.15 \text{ ft}$

$A = 2\pi r_o L$
 $= 2\pi \left(\frac{3.25}{12}\right) (1.0)$
 $= 1.70 \text{ ft}^2/\text{ft}$

$Re = \frac{D_o \dot{m}_{in}}{\mu_f} = \frac{\rho_f D_o \dot{m}_{in}}{\mu_f}$

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS
 AMPAD

$$10 \frac{\text{mile}}{\text{hr}} \left(\frac{5280 \text{ ft}}{\text{mile}} \right) = 52800 \frac{\text{ft}}{\text{hr}}$$

$$Re = \frac{\left(\frac{6.5}{12} \right) (52800) (0.084)}{.04} \quad \mu_f = .04 \frac{\text{lb}_m}{\text{hr-ft}}$$
$$= 60000$$

$$\frac{hD_o}{k_f} = 170 \quad (\text{see pg 7})$$

$$h = \frac{170 (.0135)}{(6.5/12)}$$

$$= 4.24 \text{ Btu/hr-ft}^2\text{-}^\circ\text{F}$$

To account for radiation, say $h = 4.5 \frac{\text{Btu}}{\text{hr-ft}^2\text{-}^\circ\text{F}}$

$$\therefore .04(10.15)(325 - T_o) = 4.5(1.70)(T_o - 15)$$

$$131.95 - .406T_o = 7.65T_o - 114.75$$

$$8.06T_o = 246.7$$

$$T_o = 30.6^\circ\text{F}$$

$$\therefore q = hS(T_i - T_o)$$
$$= .04(10.15)(325 - 30.6)$$
$$= 119.5 \frac{\text{Btu}}{\text{hr-ft}}$$

For 60 ft of pipe

$$\dot{q} = 119.5(60) = 7172 \text{ Btu/hr}$$



∴ Calculate the temp drop of the
N₂ inside the pipe

$$q = \dot{m} c_p \Delta T$$

$$7172 = .22(3600)(.25) \Delta T$$

$$\Delta T = 36^\circ \text{F}$$


N₂ temp in needs to be

$$\begin{array}{r} 325 \\ + 36 \\ \hline 361^\circ \text{F} \end{array} \quad \text{say } 360^\circ \text{F}$$

//

Short pump

1/2" ϕ pipe
(1.9" o.d.)



1/2" insul

- 50 gm/sec
(.11 lbm/sec)

$$S = \frac{2\pi(1.0)}{\ln(4.9/1.9)} = 6.63 \text{ ft}$$

$$A = 2\pi \left(\frac{4.9}{2(12)} \right) (1.0) = 1.28 \text{ ft}^2/\text{ft}$$

10 mph. wind

$$Re = \frac{\left(\frac{4.9}{12} \right) (52800) (.084)}{.04} = 45300$$

$$\frac{h D_o}{k_f} = 150 \quad (\text{see pg 7})$$

$$h = \frac{150 (.0135)}{(4.9/12)}$$

$$= 4.96 \text{ Btu/hr-ft}^2\text{-}^\circ\text{F}$$

say 5.5 Btu/hr-ft²-°F

$$kS(T_i - T_o) = hA(T_o - T_{amb})$$

$$.04(6.63)(325 - T_o)$$

$$= 5.5(1.28)(T_o - 15)$$

$$86.19 - .265T_o = 7.04T_o - 105.6$$

$$191.8 = 7.305T_o$$

$$T_o = 26.3^\circ\text{F}$$

$$q = kS(T_i - T_o)$$

$$= .04(6.63)(325 - 26.3)$$

$$= 79.21 \text{ Btu/hr-ft}$$

for 60 ft of pipe

$$q = 60(79.21) = 4753 \text{ Btu/hr}$$

∴ Temp drop of N₂:

$$q = \dot{m} c_p \Delta T$$

$$4753 = .11(3600)(.25)\Delta T$$


$$\Delta T = 48^\circ\text{F}$$

∴ T_{in} must be

$$\begin{array}{r} 325 \\ + 48 \\ \hline 373 \text{ (say } 375^\circ\text{F)} \end{array}$$



Fig. 6-9 Data for heating and cooling of air flowing normal to single cylinders, from McAdams [10].



Regen Heater Sizes:

Vaporizer design is based on 20°F approach temp. ∴ the N₂ gas out of the vaporizer will be 15°F - 20°F = -5°F (253 K)

Long pump:

100 gm/sec. flowrate at 253K
raised to 455K (360°F)

$$Q = \left(100 \frac{\text{gm}}{\text{sec}}\right) (472.8 - 262) \frac{\text{J}}{\text{gm}}$$

$$= 21080 \text{ watts}$$

(Heater size approx 25 kW)

100 gm/sec → 10572 SCFH (say 10600 SCFH)

Short pump:

50 gm/sec. flowrate at 253K raised to
469K (375°F)

$$Q = 50 \frac{\text{gm}}{\text{sec}} (482.3 - 262) \frac{\text{J}}{\text{gm}}$$

$$= 11015 \text{ watts (Heater size approx 12 kW)}$$

50 gm/sec → say 5300 SCFH



Time to vaporize LN₂:

Long pump: ~ 1700 lbm of LN₂ (772,700 gm)
Purge gas flow = 100 gm/sec.
@ 253K

$$(\dot{m} \Delta h)_{N_2 \text{ gas}} = \dot{m} h_{fg}$$

$$\dot{m}_{\text{vaporized}} = \frac{(\dot{m} \Delta h)_{N_2 \text{ gas}}}{h_{fg}}$$

$$= \frac{(100 \text{ gm/sec})(262 - 79.6) \text{ J/gm}}{(78.4 + 118.1) \text{ J/gm}}$$

$$= 92.8 \text{ gm/sec}, (.204 \text{ lbm/sec})$$

∴ Time to vaporize is:

$$t = \frac{1702 \text{ lbm}}{.204 \text{ lbm/sec}}$$

$$= 8324 \text{ sec} (2.3 \text{ hr.})$$

Short pump: ~ 550 lbm of N₂
Purge gas flow = 50 gm/sec.

$$\dot{m}_{\text{vaporized}} = \frac{(50)(262 - 79.6)}{(78.4 + 118.1)}$$

$$= 46.4 \text{ gm/sec} (.102 \text{ lbm/sec})$$

∴ Time to vaporize is:

$$t = \frac{550}{.102} = 5392 \text{ sec} (1.5 \text{ hr.})$$

Long Pump Regen.
Warmup Time
Winter Conditions

N2 flow (gm/sec)	Cp of N2 (j/gm-K)	N2 in (K)	N2 out (K)	Cp alum. (j/gm-K)	Initial alum. temp (K)	Final alum. temp. (K)	Alum. mass (gm.)	Elapsed time (sec)
50	1.05	253	80	0.357	80	100	1341000	1054.2
50	1.05	253	100	0.481	100	120	1341000	2660.22
50	1.05	253	120	0.58	120	140	1341000	4888.02
50	1.05	253	140	0.654	140	160	1341000	7844.66
50	1.05	253	160	0.713	160	180	1341000	11761.2
50	1.05	253	180	0.76	180	200	1341000	17079.7
50	1.05	253	200	0.797	200	220	1341000	24761.9
100	1.05	436	220	0.826	220	240	1341000	25738.7
100	1.05	436	240	0.849	240	260	1341000	26845.1
100	1.05	436	260	0.869	260	280	1341000	28106.3
100	1.05	436	280	0.886	280	300	1341000	29557
100	1.05	436	300	0.902	300	320	1341000	31251.1
100	1.05	436	320	0.918	320	340	1341000	33272.5
100	1.05	436	340	0.934	340	360	1341000	35757.6
100	1.05	436	360	0.934	360	380	1341000	38896.7
100	1.05	436	380	0.934	380	400	1341000	43156.8
100	1.05	436	400	0.934	400	420	1341000	49783.8
100	1.05	436	420	0.934	420	423	1341000	52020.4

Time to vaporize LN2 = 2.3 hours
Total warmup time = 16.75 hours

Short Pump Regen.
Warmup Time
Winter Conditions

N2 flow (gm/sec)	Cp of N2 (j/gm-K)	N2 in (K)	N2 out (K)	Cp alum. (j/gm-K)	Initial alum. temp (K)	Final alum. temp. (K)	Alum. mass (gm.)	Elapsed time (sec)
50	1.05	253	80	0.357	80	100	398000	312.879
50	1.05	253	100	0.481	100	120	398000	789.537
50	1.05	253	120	0.58	120	140	398000	1450.73
50	1.05	253	140	0.654	140	160	398000	2328.25
50	1.05	253	160	0.713	160	180	398000	3490.66
50	1.05	253	180	0.76	180	200	398000	5069.16
50	1.05	253	200	0.797	200	220	398000	7349.16
50	1.05	436	220	0.826	220	240	398000	7928.97
50	1.05	436	240	0.849	240	260	398000	8585.73
50	1.05	436	260	0.869	260	280	398000	9334.34
50	1.05	436	280	0.886	280	300	398000	10195.5
50	1.05	436	300	0.902	300	320	398000	11201.1
50	1.05	436	320	0.918	320	340	398000	12400.9
50	1.05	436	340	0.934	340	360	398000	13876.1
50	1.05	436	360	0.934	360	380	398000	15739.4
50	1.05	436	380	0.934	380	400	398000	18268.2
50	1.05	436	400	0.934	400	420	398000	22201.8
50	1.05	436	420	0.934	420	423	398000	23529.5

Time to vaporize LN2 = 1.5 hours
Total warmup time = 8.036 hours

Attachment 1.

Table C-1 (Cont.)

STATE AND STATION	WINTER		SUMMER			STATE AND STATION	WINTER		SUMMER		
	Latitude	DB 97%	DB 2%	WB 2%	Outdoor Daily Range		Latitude	DB 97%	DB 2%	WB 2%	Outdoor Daily Range
Lubbock AP	33	15	97	72	26	Everett-Paine AFB	47	24	78	65	20
Lufkin AP	31	28	96	80	20	Kennewick	46	15	96	68	30
McAllen	26	38	100	79	21	Longview	46	24	86	66	30
Midland AP	32	23	98	73	26	Moses Lake, Larson AFB	47	-1	93	66	32
Mineral Wells AP	32	22	100	77	22	Olympia AP	47	25	83	65	32
Palestine CO	31	25	97	79	20	Port Angeles	48	29	73	58	18
Pampa	35	11	98	72	26	Seattle-Boeing Fld.	47	27	80	65	24
Pecos	31	19	100	71	27	Seattle CO	47	32	79	65	19
Plainview	34	14	98	72	26	Seattle-Tacoma AP	47	24	81	64	22
Port Arthur AP	30	33	92	80	19	Spokane AP	47	4	90	64	28
San Angelo, Goodfellow AFB	31	25	99	75	24	Tacoma-McChord AFB	47	24	81	66	22
San Antonio AP	29	30	97	77	19	Walla Walla AP	46	16	96	68	27
Sherman-Perrin AFB	33	23	99	78	22	Wenatchee	47	9	92	66	32
Snyder	32	19	100	74	26	Yakima AP	46	10	92	67	36
Temple	31	27	99	78	22	WEST VIRGINIA					
Tyler AP	32	24	97	79	21	Beckley	37	6	88	73	22
Vernon	34	18	101	76	24	Bluefield AP	37	10	86	73	22
Victoria AP	28	32	96	79	18	Charleston AP	38	14	90	75	20
Waco AP	31	26	99	78	22	Clarksburg	39	7	90	75	21
Wichita Falls AP	34	19	100	76	24	Elkins AP	38	5	84	73	22
UTAH						Huntington CO	38	14	93	76	22
Cedar City AP	37	6	91	64	32	Martinsburg AP	39	7	94	77	21
Logan	41	7	91	65	33	Morgantown AP	39	7	88	74	22
Moab	38	16	98	65	30	Parkersburg CO	39	12	91	76	21
Ogden CO	41	11	92	65	33	Wheeling	40	9	89	75	21
Price	39	7	91	64	33	WISCONSIN					
Provo	40	6	93	66	32	Appleton	44	-6	87	74	23
Richfield	38	3	92	65	34	Ashland	46	-17	83	71	23
St. George CO	37	26	102	70	33	Beloit	42	-3	90	76	24
Salt Lake City AP	40	9	94	66	32	Eau Claire AP	44	-11	88	74	23
Vernal AP	40	-6	88	63	32	Fond du Lac	43	-7	87	74	23
VERMONT						Green Bay AP	44	-7	85	73	23
Barre	44	-13	84	72	23	La Crosse AP	43	-8	88	76	22
Burlington AP	44	-7	85	73	23	Madison AP	43	-5	88	75	22
Rutland	43	-8	85	73	23	Manitowoc	44	-1	86	74	21
VIRGINIA						Marinette	45	-4	86	72	20
Charlottesville	38	15	90	77	23	Milwaukee AP	43	-2	87	75	21
Danville AP	36	17	92	77	21	Racine	42	0	88	75	21
Fredericksburg	38	14	92	78	21	Sheboygan	43	0	87	74	20
Harrisonburg	38	9	90	77	23	Stevens Point	44	-12	87	73	23
Lynchburg AP	37	19	92	76	21	Waukesha	43	-2	89	75	22
Norfolk AP	36	23	91	78	18	Wausau AP	44	-14	86	72	23
Petersburg	37	18	94	79	20	WYOMING					
Richmond AP	37	18	93	78	21	Casper AP	42	-5	90	62	31
Roanoke AP	37	18	91	75	23	Cheyenne AP	41	-2	86	62	30
Staunton	38	12	90	77	23	Cody AP	44	-9	87	60	32
Winchester	39	10	92	76	21	Evanston	41	-8	82	57	32
WASHINGTON						Lander AP	42	-12	90	62	32
Aberdeen	47	27	80	61	16	Laramie AP	41	-2	80	59	28
Bellingham AP	48	18	74	65	19	Newcastle	43	-5	89	67	30
Bremerton	47	29	81	66	20	Rawlins	41	-11	84	61	40
Ellensburg AP	47	6	89	65	34	Rock Springs AP	41	-1	84	57	32
						Sheridan AP	44	-7	92	65	32
						Torrington	42	-7	92	67	30

EXPLANATION OF DESIGN CONDITIONS:

WINTER - 97% indicates that the temperature will be at or above the design temperature shown 97% of the time.

SUMMER - 2% indicates that the temperature will exceed the design temperature shown only 2% of the time.

OUTDOOR DAILY RANGE - The outdoor daily range of DB temperatures is the difference between the average maximum and average minimum temperatures during the warmest month at each location. Refer to page 39 when outdoor daily range is other than 20°.

22-141 50 SHEETS
 22-142 100 SHEETS
 22-144 200 SHEETS



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1- 116 PAGE 1 OF 21
REV.	DEO #	DATE	BY:	CHECK	TITLE: 80K Pump Liquid Supply Valve Sizing	
0	SS11	10/17/96	EM	D. Moore		
					BY: D. Moore	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> Calculate required Cv for the liquid supply valve for the range of operating conditions that the pump will experience.						
<u>METHOD:</u> Standard ISA formulas used in sizing control valves for two phase flow. Calculations have been programmed.						
<u>ASSUMPTIONS:</u> a) Liquid nitrogen dewar full. b) Liquid nitrogen dewar 20% full c) 80K pump clean d) 80K pump frosted						
<u>INPUTS:</u>						
<u>REFERENCES:</u> ISA SP39.1 formulas for control valve sizing (excerpt of paper attached).						
<u>CALCULATIONS:</u> (SEE ATTACHED)						
<u>CONCLUSIONS:</u> Use valve plug with maximum Cv of 0.05. Minimum requirement is 0.0056.						
<u>NOTES:</u>						

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-116
		Rev. No. 0
		Page 2 of 21
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO: "	V59049
CALCULATION TITLE: 80K Pump Liquid Supply Valve Sizing		

REVISION HISTORY

Rev. 0 Original Issue -Oct. 17, 1996


LN₂ Dewar Short Pump

Set regulator at 5 psig (top of tank)

Pressure at control valve is 5 psig + liquid head

Tank full : $5 + 8 = 13$ psig at valve

Tank "empty" : 5 psig at valve
(~20% full)




* approx. 20% of height of dewar

LN₂ Dewar Long Pump

Set regulator at 5 psig (top of tank)
Pressure at control valve is 5 psig + liquid head

Tank full : $5 + 10 = 15$ psig at valve


Tank "empty" : 5 psig at valve
(~16.5% full)



* approx 16.5% of height of dewar

Short Pump

"J" LINEAR



① Clean, 13 psid ΔP (Tank full)

② Clean, 5 psid ΔP (Tank 20% full)

③ Frosted, 5 psid ΔP

④ Frosted, 13 psid ΔP


⑤ Clean, 13 psid ΔP, subcooled water

- ①
- ②
- ③
- ④
- ⑤

Ver 1-11-16, Rev 0
 P. 11-11-16

Long Pump

"J" LINEAR




Frosted, 5 psid ΔP (Tank 16.5% full) LIFI
 Clean, 5 psid ΔP
 Frosted, 15 psid ΔP (Tank full)
 Clean, 15 psid ΔP
 Clean, 15 psid ΔP, Subcooled liquid

- ①
- ②
- ③
- ④
- ⑤

V049-1-116, Rev 0
 P. 0 of 2

Short Pump
Smaller CV

"K" Linear



- ① Pump clean, 13 psid ΔP (Dewar full)
- ② Pump clean, 5 psid ΔP (Dewar 20% full)
- ③ Pump frosted, 5 psid ΔP
- ④ Pump frosted, 13 psid ΔP
- ⑤ Pump clean, 13 psid ΔP, liquid subcooled

LIQUID LIQUID SUPPLY VALVE

REQUIRED CV FOR FROSTED LONG PUMP, 5 PSID AVAILABLE

LIQUID FLOW RATE THRU VALVE = 31.410 LBM/HR
LIQUID DENSITY = 49.690 LBM/FT**3
VAPOR DENSITY = .383 LBM/FT**3
VAPOR PRESSURE = 14.700 PSIA
CRITICAL PRESSURE = 492.000 PSIA
VALVE DELTA P = 5.000 PSID
CF(CRITICAL FLOW FACTOR) = .90
PRESSURE UPSTREAM OF VALVE = 19.700 PSIA
UPSTREAM FLUID QUALITY = .000
FLOW IS SUBCRITICAL ACROSS VALVE
DELTA P USED IN SIZING FORMULA = 5.000 PSID
REQUIRED VALVE CV = .031

Commands PGUP PGDN HOME END 1..9 scroll ↓ (H)ex (N)ormal (S)earch

LIGO LIQUID SUPPLY VALVE

REQUIRED CV FOR CLEAN LONG PUMP, 5 PSID AVAILABLE

LIQUID FLOW RATE THRU VALVE = 19.240 LBM/HR
LIQUID DENSITY = 49.690 LBM/FT**3
VAPOR DENSITY = .383 LBM/FT**3
VAPOR PRESSURE = 14.700 PSIA
CRITICAL PRESSURE = 492.000 PSIA
VALVE DELTA P = 5.000 PSID
CF(CRITICAL FLOW FACTOR) = .90
PRESSURE UPSTREAM OF VALVE = 19.700 PSIA
UPSTREAM FLUID QUALITY = .000
FLOW IS SUBCRITICAL ACROSS VALVE
DELTA P USED IN SIZING FORMULA = 5.000 PSID
REQUIRED VALVE CV = .019

Commands PGUP PGDN HOME END 1..9 scroll ↓ (H)ex (N)ormal (S)earch

FRIGO LIQUID SUPPLY VALVE

REQUIRED CV FOR FROSTED LONG PUMP, 15 PSID AVAILABLE

LIQUID FLOW RATE THRU VALVE = 31.410 LBM/HR
LIQUID DENSITY = 49.690 LBM/FT**3
VAPOR DENSITY = .383 LBM/FT**3
VAPOR PRESSURE = 14.700 PSIA
CRITICAL PRESSURE = 492.000 PSIA
VALVE DELTA P = 15.000 PSID
CF(CRITICAL FLOW FACTOR) = .90
PRESSURE UPSTREAM OF VALVE = 29.700 PSIA
UPSTREAM FLUID QUALITY = .000
CRITICAL FLOW CAVITATION OR FLASHING FLOW EXISTS
REQUIRED VALVE CV = .019

Commands PGUP PGDN HOME END 1..9 scroll ↓ (H)ex (N)ormal (S)earch

WAGO LIQUID SUPPLY VALVE

REQUIRED CV FOR CLEAN LONG PUMP, 15 PSID AVAILABLE

LIQUID FLOW RATE THRU VALVE = 19.240 LBM/HR
LIQUID DENSITY = 49.690 LBM/FT**3
VAPOR DENSITY = .383 LBM/FT**3
VAPOR PRESSURE = 14.700 PSIA
CRITICAL PRESSURE = 492.000 PSIA
VALVE DELTA P = 15.000 PSID
CF(CRITICAL FLOW FACTOR) = .90
PRESSURE UPSTREAM OF VALVE = 29.700 PSIA
UPSTREAM FLUID QUALITY = .000
CRITICAL FLOW CAVITATION OR FLASHING FLOW EXISTS
REQUIRED VALVE CV = .012

Commands PGUP PGDN HOME END 1..9 scroll ↓ (H)ex (N)ormal (S)earch

GO LIQUID SUPPLY VALVE

REQUIRED CV FOR CLEAN SHORT PUMP, 13 PSID AVAILABLE

LIQUID FLOW RATE THRU VALVE = 9.000 LBM/HR
LIQUID DENSITY = 49.690 LBM/FT**3
VAPOR DENSITY = .383 LBM/FT**3
VAPOR PRESSURE = 14.700 PSIA
CRITICAL PRESSURE = 492.000 PSIA
VALVE DELTA P = 13.000 PSID
CF (CRITICAL FLOW FACTOR) = .90
PRESSURE UPSTREAM OF VALVE = 27.700 PSIA
UPSTREAM FLUID QUALITY = .000
CRITICAL FLOW CAVITATION OR FLASHING FLOW EXISTS
REQUIRED VALVE CV = .006

Commands PGUP PGDN HOME END 1..9 scroll ↓ (H)ex (N)ormal (S)earch

LIQUID SUPPLY VALVE

REQUIRED CV FOR CLEAN SHORT PUMP, 5 PSID AVAILABLE

LIQUID FLOW RATE THRU VALVE = 9.000 LBM/HR
LIQUID DENSITY = 49.690 LBM/FT**3
VAPOR DENSITY = .383 LBM/FT**3
VAPOR PRESSURE = 14.700 PSIA
CRITICAL PRESSURE = 492.000 PSIA
VALVE DELTA P = 5.000 PSID
CF(CRITICAL FLOW FACTOR) = .90
PRESSURE UPSTREAM OF VALVE = 19.700 PSIA
UPSTREAM FLUID QUALITY = .000
FLOW IS SUBCRITICAL ACROSS VALVE
DELTA P USED IN SIZING FORMULA = 5.000 PSID
REQUIRED VALVE CV = .009

Commands PGUP PGDN HOME END 1..9 scroll ↓ (H)ex (N)ormal (S)earch

0 LIQUID SUPPLY VALVE

REQUIRED CV FOR FROSTED SHORT PUMP, 5 PSID AVAILABLE

LIQUID FLOW RATE THRU VALVE = 24.690 LBM/HR
LIQUID DENSITY = 49.690 LBM/FT**3
VAPOR DENSITY = .383 LBM/FT**3
VAPOR PRESSURE = 14.700 PSIA
CRITICAL PRESSURE = 492.000 PSIA
VALVE DELTA P = 5.000 PSID
CF(CRITICAL FLOW FACTOR) = .90
PRESSURE UPSTREAM OF VALVE = 19.700 PSIA
UPSTREAM FLUID QUALITY = .000
FLOW IS SUBCRITICAL ACROSS VALVE
DELTA P USED IN SIZING FORMULA = 5.000 PSID
REQUIRED VALVE CV = .025

Commands PGUP PGDN HOME END 1..9 scroll ↓ (H)ex (N)ormal (S)earch

LIQUID SUPPLY VALVE

REQUIRED CV FOR FROSTED SHORT PUMP, 13 PSID AVAILABLE

LIQUID FLOW RATE THRU VALVE = 24.690 LBM/HR
LIQUID DENSITY = 49.690 LBM/FT**3
VAPOR DENSITY = .383 LBM/FT**3
VAPOR PRESSURE = 14.700 PSIA
CRITICAL PRESSURE = 492.000 PSIA
VALVE DELTA P = 13.000 PSID
CF(CRITICAL FLOW FACTOR) = .90
PRESSURE UPSTREAM OF VALVE = 27.700 PSIA
UPSTREAM FLUID QUALITY = .000
CRITICAL FLOW CAVITATION OR FLASHING FLOW EXISTS
REQUIRED VALVE CV = .016

Commands PGUP PGDN HOME END 1..9 scroll ↓ (H)ex (N)ormal (S)earch

V029-1-116, Rev 3
Pg 14 of 21

LIGO LIQUID SUPPLY VALVE

REQUIRED CV FOR CLEAN SHORT PUMP, 13 PSID AVAILABLE, SUBCOOLED CASE

LIQUID SERVICE

LIQUID FLOW RATE THRU VALVE = 9.000 LBM/HR

LIQUID DENSITY = 49.690 LBM/FT**3

VAPOR DENSITY = .383 LBM/FT**3

VAPOR PRESSURE = 14.700 PSIA

CRITICAL PRESSURE = 492.000 PSIA

VALVE DELTA P = 13.000 PSID

PRESSURE UPSTREAM OF VALVE = 27.700 PSIA

UPSTREAM FLUID QUALITY = .000

REQUIRED VALVE CV = .0056

LIGO LIQUID SUPPLY VALVE

REQUIRED CV FOR CLEAN LONG PUMP, 15 PSID AVAILABLE, SUBCOOLED CASE

LIQUID SERVICE

LIQUID FLOW RATE THRU VALVE = 19.240 LBM/HR

LIQUID DENSITY = 49.690 LBM/FT**3

VAPOR DENSITY = .383 LBM/FT**3

VAPOR PRESSURE = 14.700 PSIA

CRITICAL PRESSURE = 492.000 PSIA

VALVE DELTA P = 15.000 PSID

PRESSURE UPSTREAM OF VALVE = 29.700 PSIA

UPSTREAM FLUID QUALITY = .000

REQUIRED VALVE CV = .0111

C-----DATE: OCT. 1996
C----- PROGRAMMER: DAVID MOORE

PROGRAM VALVSIZ2
VERSION 2.0

C--- THESE COMPUTATIONS ARE FOR 2 PHASE FLOW AND LIQUID FLOW THRU VALVES
C--- FORMULAS ARE COMPATIBLE WITH ISA SP39.1 AND ARE FROM MASONNEILAN
C--- PAPER ON CONTROL VALVE SIZING.

C--- NOTE: NO LOGIC IS PRESENTLY IN THIS CODE TO ACCOUNT FOR
C--- NON-CONDENSABLE GAS.

REAL MDOTL
CHARACTER TITLE1*80,TITLE2*80
OPEN(UNIT=10,FILE='VALVSIZ.DAT',ACCESS='SEQUENTIAL',STATUS='OLD',
+ FORM='FORMATTED')
OPEN(UNIT=11,FILE='VALVSIZ.OUT',ACCESS='SEQUENTIAL',STATUS='OLD',
+ FORM='FORMATTED')

\$DEBUG

C-----READ DATA-----

READ(10,*) TITLE1
READ(10,*) TITLE2
WRITE(11,*) TITLE1
WRITE(11,*) TITLE2

C--- READ VALUE OF FLAGS. IF FLAG1 IS GREATER THAN 0.0, CALCULATE THE
C--- FLOWRATE WHEN GIVEN THE CV AND VALVE DP. OTHERWISE CALCULATE
- THE REQ'D CV. FLAG2 GREATER THAN 0.0 IS FOR LIQUID SERVICE.

READ(10,*) FLAG1,FLAG2

C--- READ CV, LIQ. DENS(LB/FT**3), LIQ. VAPOR PRESS AT FLOWING TEMP(Psia),
C--- THERMODYNAMIC CRITICAL PRESS.(PSIA), DELTA P ACROSS VALVE(PSIA)
IF(FLAG1.GT.0.0.AND.FLAG2.EQ.0.0) THEN

C-----FLASHING FLOW

READ(10,*) CV,RHOL,RHOV,VAPRES,CRPRES,DPVALV,CF,P1,X
WRITE(11,100)CV
WRITE(11,101)RHOL
WRITE(11,111)RHOV
WRITE(11,102)VAPRES
WRITE(11,103)CRPRES
WRITE(11,104)DPVALV
WRITE(11,105)CF
WRITE(11,106)P1
WRITE(11,110)X
DPMAX=CF**2*P1/2.0
DPS=P1-(0.96-0.28*SQRT(VAPRES/CRPRES))*VAPRES

CF2DP=CF**2*DPS
DPWL=DPVALV*(RHOL/62.4/(RHOL/62.365))
IF(CF2DP.LT.DPWL) THEN
WRITE(11,107)

C--- CRITICAL FLOW CAVITATION OR FLASHING FLOW EXISTS
MDOTL=CV*500*CF*SQRT(DPS*(RHOL/62.365))
WRITE(11,109)MDOTL

ELSE

WRITE(11,112)

C--- FLOW IS TWO-PHASE LIQUID & VAPOR, NO NON-CONDENSABLES & NO CHOKING

VO 49-1-116, Rev D
Pg 7 of 21

```
W1=1.0/(X*(1/RHOV+1/RHOL)+1/RHOL)
IF(DPVALV.GE.DPMAX) THEN
```

```
C--- MAX DELTA P FOR SIZING SUBSTITUTED FOR DPVALV
DPVALV=DPMAX
WRITE(11,108)DPVALV
ELSE
WRITE(11,108)DPVALV
END IF
```

```
MDOTL=CV*63.3*SQRT(DPVALV*W1)
WRITE(11,109)MDOTL
```

```
END IF
```

```
ELSE IF(FLAG1.GT.0.0.AND.FLAG2.GT.0.0) THEN
```

```
READ(10,*) CV,RHOL,RHOV,VAPRES,CRPRES,DPVALV,CF,P1,X
```

```
C--- LIQUID OR SUBCOOLED SERVICE
```

```
WRITE(11,114)
```

```
MDOTL=CV*500*SQRT(RHOL/62.4*DPVALV)
```

```
WRITE(11,109)MDOTL
```

```
ELSE IF(FLAG1.EQ.0.0.AND.FLAG2.EQ.0.0) THEN
```

```
READ(10,*) CV,RHOL,RHOV,VAPRES,CRPRES,DPVALV,CF,P1,X
```

```
C---- FLASHING FLOW
```

```
C--- CODE HERE FOR CALCULATION OF CV WHEN GIVEN FLOW RATE
```

```
READ(10,*) MDOTL,RHOL,RHOV,VAPRES,CRPRES,DPVALV,CF,P1,X
```

```
WRITE(11,109)MDOTL
```

```
WRITE(11,101)RHOL
```

```
WRITE(11,111)RHOV
```

```
WRITE(11,102)VAPRES
```

```
WRITE(11,103)CRPRES
```

```
WRITE(11,104)DPVALV
```

```
WRITE(11,105)CF
```

```
WRITE(11,106)P1
```

```
WRITE(11,110)X
```

```
DPMAX=CF**2*P1/2.0
```

```
DPS=P1-(0.96-0.28*SQRT(VAPRES/CRPRES))*VAPRES
```

```
C
```

```
CF2DP=CF**2*DPS
```

```
DPWL=DPVALV*(RHOL/62.4/(RHOL/62.365))
```

```
IF(CF2DP.LT.DPWL) THEN
```

```
WRITE(11,107)
```

```
C--- CRITICAL FLOW CAVITATION OR FLASHING FLOW EXISTS
```

```
CV=MDOTL/(500*CF*SQRT(DPS*(RHOL/62.365)))
```

```
WRITE(11,113)CV
```

```
ELSE
```

```
WRITE(11,112)
```

```
C--- FLOW IS TWO-PHASE LIQUID & VAPOR, NO NON-CONDENSABLES & NO CHOKING
```

```
W1=1.0/(X*(1/RHOV+1/RHOL)+1/RHOL)
```

```
IF(DPVALV.GE.DPMAX) THEN
```

```
C--- MAX DELTA P FOR SIZING SUBSTITUTED FOR DPVALV
```

```
DPVALV=DPMAX
```

```
WRITE(11,108)DPVALV
```

```
ELSE
```

```
WRITE(11,108)DPVALV
```

```
END IF
```

```
CV=MDOTL/(63.3*SQRT(DPVALV*W1))
```

```
WRITE(11,113)CV
```

```
END IF
```

```
ELSE IF(FLAG1.EQ.0.0.AND.FLAG2.GT.0.0) THEN
```

```
READ(10,*) MDOTL,RHOL,RHOV,VAPRES,CRPRES,DPVALV,CF,P1,X
```

```
WRITE(11,114)
```

```
WRITE(11,109)MDOTL
```

```
WRITE(11,101)RHOL
```

V049-1-116, Rev 3
Pg 18 of 21

```
WRITE (11,111) RHOV
WRITE (11,102) VAPRES
WRITE (11,103) CRPRES
WRITE (11,104) DPVALV
WRITE (11,105) CF
WRITE (11,106) P1
WRITE (11,110) X
```

```
C--- LIQUID OR SUBCOOLED SERVICE
      CV=MDOTL/500/SQRT (RHOL/62.4*DPVALV)
      WRITE (11,113) CV
      ELSE
      END IF
```

C
C
C
C
C

```
C-----FORMATS FOR INPUT AND OUTPUT STATEMENTS-----
```

```
90 FORMAT (3X,I2)
100 FORMAT (10X,'VALVE CV = ',F6.2)
101 FORMAT (10X,'LIQUID DENSITY = ',F8.3,' LBM/FT**3')
102 FORMAT (10X,'VAPOR PRESSURE = ',F8.3,' PSIA')
103 FORMAT (10X,'CRITICAL PRESSURE = ',F8.3,' PSIA')
104 FORMAT (10X,'VALVE DELTA P = ',F8.3,' PSID')
105 FORMAT (10X,'CF(CRITICAL FLOW FACTOR) = ',F6.2)
106 FORMAT (10X,'PRESSURE UPSTREAM OF VALVE = ',F8.3,' PSIA')
107 FORMAT (10X,'CRITICAL FLOW CAVITATION OR FLASHING FLOW EXISTS')
108 FORMAT (10X,'DELTA P USED IN SIZING FORMULA = ',F6.3,' PSID')
109 FORMAT (10X,'LIQUID FLOW RATE THRU VALVE = ',F8.3,' LBM/HR')
110 FORMAT (10X,'UPSTREAM FLUID QUALITY = ',F6.3)
111 FORMAT (10X,'VAPOR DENSITY = ',F8.3,' LBM/FT**3')
112 FORMAT (10X,'FLOW IS SUBCRITICAL ACROSS VALVE')
113 FORMAT (10X,'REQUIRED VALVE CV = ',F9.4)
114 FORMAT (10X,'LIQUID SERVICE')
216 CONTINUE
      CLOSE (UNIT=10)
      CLOSE (UNIT=11)
      STOP
      END
```

two-phase flow

The two-phase flow formulas, shown below, assume finely divided liquid particles in vapor moving at the same velocity. If insufficient vapor exists entering the valve, the flashing formula on page 3 will prevail.

Therefore:

when $C_v^2 \Delta P_1 < \Delta P \left(\frac{w_1}{62.4 G_1} \right)$, use flashing formula on page 3.

ENGLISH FORMULAS:

- A. Liquid And Non-Condensable Gas Entering Valve
If there is no vaporization of the liquid and if flow velocity assures a turbulent well-mixed stream.

$$C_v = \frac{W}{44.8 \sqrt{\Delta P (w_1 + w_2)}}$$

- B. Liquid And Its Vapor Entering Valve
Additional vaporization of liquid occurs. If flow velocity assures a turbulent well-mixed stream.

$$C_v = \frac{W}{63.3 \sqrt{\Delta P w_1}}$$

Where:

$$\text{Max. } \Delta P \text{ For Sizing} = C_v^2 \left(\frac{P_1}{2} \right)$$

w_1 = Upstream specific weight lb/cu. ft. calculated from weight fraction of gas or vapor

in the stream X_g and specific volumes of gas or vapor and liquid at upstream pressure V_{g1} and V_l .

$$w_1 = \frac{1}{V_1} = \frac{1}{X_g (V_{g1} - V_l) + V_l}$$

w_2 = Downstream specific weight, lb/cu. ft. calculated using downstream gas specific volume V_{g2} .

$$w_2 = \frac{1}{V_2} = \frac{1}{X_g (V_{g2} - V_l) + V_l}$$

METRIC FORMULAS:

- A. Liquid And Non-Condensable Gas Entering Valve

$$C_v = \frac{51.8 W}{\sqrt{\Delta P (w_1 + w_2)}}$$

- B. Liquid And Its Vapor Entering Valve

$$C_v = \frac{36.6 W}{\sqrt{\Delta P w_1}}$$

Where:

w_1 = Upstream specific weight, (kg/m³)

w_2 = Downstream specific weight, (kg/m³)

compressibility

For many real gases subjected to commonly encountered temperatures and pressures the perfect gas laws are not satisfactory for flow measurement accuracy and correction factors must be used (Ref. 9).

Following conventional flow measurement practice, the compressibility factor Z in the equation $pv = ZRT$ will be used. Z can usually be ignored below 100 psi for common gases.

The value of Z does not differ materially for different gases when correlated as a function of the reduced temperature and reduced pressure, T_r and P_r , respectively and found from Figure 2 and 3.

Figure 2 is an enlargement of a portion of Figure 3. Values taken from these figures are probably accurate to approximately plus or minus two percent.

To obtain the value of Z for a pure substance the reduced pressure and reduced temperature are calculated as the ratio of the actual absolute gas pressure and absolute temperature and the corresponding critical absolute pressure and absolute critical temperature respectively (page 16).

The compressibility factor Z may be used directly in the volumetric gas formula as shown below:

ENGLISH UNITS

$$C_v = \frac{Q \sqrt{GTZ}}{834 C_1 P_1 (y - 0.148 y^3)}$$

METRIC UNITS

$$C_v = \frac{Q \sqrt{GTZ}}{257 C_1 P_1 (y - 0.148 y^3)}$$

English Units
Metric Units




Figure 2
Compressibility Factors for Gases with
Reduced Pressures from 0 to 6
(Data from the charts of L. C. Nelson and E. F. Obert,
Northwestern Technological Institute)

1049-1-16, Rev 0
Pg 20 of 21

control valve sizing formulas

For Liquid Service

ENGLISH FORMULAS:

- A. Subcritical Flow $\Delta P < C_v^2 (\Delta P_s)$
- B. Critical Flow cavitation or flashing $\Delta P \geq C_v^2 (\Delta P_s)$

Volumetric Flow

$$C_v = q \sqrt{\frac{G_f}{\Delta P}}$$

Flow by Weight

$$C_v = \frac{W}{500 \sqrt{G_f \Delta P}}$$

$$C_v = \frac{q}{C_f} \sqrt{\frac{G_f}{\Delta P}}$$

$$C_v = \frac{W}{500 C_f \sqrt{G_f \Delta P}}$$

$$\Delta P_s = P_1 - \left(0.96 - 0.28 \sqrt{\frac{P_v}{P_c}}\right) P_1$$

or for simplicity, if $P_2 < 0.5 P_1$, $\Delta P_s = P_1 - P_2$

Where:

- C_v = Valve flow coefficient
- C_f = Critical flow factor (page 7) = $\frac{f_L}{f_{w @ 60^\circ F}}$
- G_f = Specific gravity at flowing temperature (water = 1 @ 60° F)
- P_1 = Upstream pressure, psia
- P_2 = Downstream pressure, psia
- P_c = Pressure at thermodynamic critical point, psia (see table, page 4)
- P_v = Vapor pressure of liquid at flowing temperature, psia
- ΔP = Actual pressure drop $P_1 - P_2$, psi
- q = Liquid flow rate, U.S. gpm
- W = Liquid flow rate, pounds per hour

METRIC FORMULAS:

- A. Subcritical Flow $\Delta P < C_v^2 (\Delta P_s)$
- B. Critical Flow cavitation or flashing $\Delta P \geq C_v^2 (\Delta P_s)$

Volumetric Flow

$$C_v = 1.16q \sqrt{\frac{G_f}{\Delta P}} \quad (\text{Ref. 1})$$

Flow by Weight

$$C_v = \frac{1.16 W}{\sqrt{G_f \Delta P}}$$

$$C_v = \frac{1.16q}{C_f} \sqrt{\frac{G_f}{\Delta P}}$$

$$C_v = \frac{1.16 W}{C_f \sqrt{G_f \Delta P}}$$

$$\Delta P_s = P_1 - \left(0.96 - 0.28 \sqrt{\frac{P_v}{P_c}}\right) P_1 \quad (\text{Ref. 2}) \quad (\text{Ref. 7})$$

or for simplicity, if $P_2 < 0.5 P_1$, $\Delta P_s = P_1 - P_2$

Where:

- C_v = Valve flow coefficient
- C_f = Critical flow factor (page 7) = $\frac{f_L}{f_{w @ 15^\circ C}}$
- G_f = Specific gravity at flowing temperature (water = 1 @ 15° C)
- P_1 = Upstream pressure, bars absolute
- P_2 = Downstream pressure, bars absolute
- P_c = Pressure at thermodynamic critical point, bars absolute (see table, page 4)
- P_v = Vapor pressure of liquid at flowing temperature, bars absolute
- ΔP = Actual pressure drop $P_1 - P_2$, bars
- q = Liquid flow rate, m³/hr
- W = Liquid flow rate, 1000 kg per hr

Note: 1 bar = 1.02 kg/cm²

- Special considerations (see following pages)
- a. cavitation in control valves (page 10)
 - b. high viscosity, laminar flow (page 14)
 - c. effect of pipe reducers (page 11)
 - d. two-phase flow (page 15)

*NOTE: $C_v^2 \Delta P_s$ is the maximum ΔP for sizing purposes. A valve is not limited in application to this pressure drop, but at higher pressure differential, choked flow will occur without increase in flow rate. This formula for ΔP_s is sufficiently accurate for general use on liquids.

†ISA Formulas: The working equations on this page are entirely compatible with the general formulas shown in ISA SP39.1, "Control Valve Sizing Equations for Incompressible Fluids."

V049-1-116, Rev 0
Pg 21 of 21